

# Meter-mounting devices



# Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

## Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

## Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

## Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

## Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



# ***Standards Update Service***

*CSA C22.2 No. 115:14*  
*July 2014*

**Title:** *Meter-mounting devices*

To register for e-mail notification about any updates to this publication

- go to [store.csagroup.org](http://store.csagroup.org)
- click on **CSA Update Service**

The **List ID** that you will need to register for updates to this publication is **2423205**.

If you require assistance, please e-mail [techsupport@csagroup.org](mailto:techsupport@csagroup.org) or call 416-747-2233.

Visit CSA Group's policy on privacy at [www.csagroup.org/legal](http://www.csagroup.org/legal) to find out how we protect your personal information.

# *CSA C22.2 No. 115:14*

## *Meter-mounting devices*



*®A trademark of the Canadian Standards Association, operating as "CSA Group"*

*Published in July 2014 by CSA Group  
A not-for-profit private sector organization  
178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3*

*To purchase standards and related publications, visit our Online Store at [store.csagroup.org](http://store.csagroup.org)  
or call toll-free 1-800-463-6727 or 416-747-4044.*

*ISBN 978-1-77139-637-0*

*© 2014 Canadian Standards Association  
All rights reserved. No part of this publication may be reproduced in any form whatsoever  
without the prior permission of the publisher.*

# Contents

Technical Committee on Industrial Products	3
Subcommittee on Meter-Mounting Devices	5
Preface	6
<b>1 Scope</b>	<b>8</b>
<b>2 Reference publications</b>	<b>9</b>
<b>3 Definitions</b>	<b>9</b>
<b>4 General requirements</b>	<b>10</b>
<b>5 Construction</b>	<b>10</b>
5.1 General	10
5.2 Enclosures	10
5.2.1 General	10
5.2.2 Protection against corrosion	11
5.2.3 Enclosures for outdoor use	11
5.2.4 Cast metal enclosures	11
5.2.5 Sheet metal enclosures	11
5.2.6 Covers	12
5.3 Meter mounting	13
5.4 Conduit openings and connections	13
5.4.1 General	13
5.4.2 Threaded conduit openings	13
5.4.3 Threaded conduit connections	14
5.4.4 Knockouts	14
5.5 Supports for bare live parts	14
5.6 Wiring terminal parts	14
5.7 Current-carrying parts	16
5.8 Fastening and support of current-carrying parts	16
5.9 Wiring	18
5.10 Spacings	18
5.11 Wiring space and wire-bending space	19
5.12 Compatibility	20
5.13 Fifth-jaw metering kits	20
5.14 Grounding and bonding	20
5.15 Self-contained meter-mounting devices with a bypass mechanism	20
5.16 Meter jaw safety guard	21
<b>6 Marking</b>	<b>21</b>
6.1 Details required	21
6.2 Mounting and wiring kits	22
6.3 Meter-mounting devices with studs for termination	22
6.4 Meter-mounting devices with automatic circuit-closers or bypass contacts	23

- 6.5 Production date 23
- 6.6 Transformer-rated meter-mounting devices 23
- 6.7 Meter-mounting devices with bypass 23
- 6.8 Self-contained meter-mounting devices with bypass 24

## **7 Tests 24**

- 7.1 Temperature 24
  - 7.1.1 Test conditions 24
  - 7.1.2 Test loads 25
  - 7.1.3 Test requirements 26
- 7.2 Contact endurance 26
- 7.3 Temperature (repeated) 26
- 7.4 Weather and humidity 27
- 7.5 Gaskets 27
- 7.6 Dielectric strength 27
- 7.7 Bonding 27
- 7.8 Heat-cycling test for joints in current-carrying parts 27
- 7.9 Mechanical strength 28
- 7.10 Rotation prevention for socket jaws and wire connectors 29
- 7.11 Connectors 29
- 7.12 Testing paint finishes 29

---

Annex A (informative) — Self-contained meter-mounting device with bypass — Suggested test sequence 46

Annex B (informative) — Self-contained meter-mounting device — Suggested test sequence 47

# Technical Committee on Industrial Products

<b>R.M. Bartholomew</b>	Electric Power Equipment Ltd, Vancouver, British Columbia <i>Category: Producer Interest</i>	<i>Chair</i>
<b>R.P. de Lhorbe</b>	Schneider Electric Canada, Inc., Richmond, British Columbia <i>Category: Producer Interest</i>	<i>Vice-Chair</i>
<b>D.P. Badry</b>	Government of Yukon, Whitehorse, Yukon <i>Category: Government and/or Regulatory Authority</i>	
<b>B.M. Baldwin</b>	Startco Engineering ULC, Saskatoon, Saskatchewan <i>Category: Producer Interest</i>	
<b>V.V. Gagachev</b>	Eaton, Burlington, Ontario <i>Category: Producer Interest</i>	
<b>D.R. MacLeod</b>	Department of Labour and Advanced Education, Halifax, Nova Scotia <i>Category: Government and/or Regulatory Authority</i>	
<b>N. Mancini</b>	Mississauga, Ontario <i>Category: General Interest</i>	
<b>D. Mascarenhas</b>	Brampton, Ontario <i>Category: General Interest</i>	
<b>D.G. Morlidge</b>	Fluor Canada Ltd., Calgary, Alberta <i>Category: General Interest</i>	
<b>T. Olechna</b>	Electrical Safety Authority, Mississauga, Ontario <i>Category: Government and/or Regulatory Authority</i>	
<b>R. Pack</b>	SaskPower, Saskatoon, Saskatchewan <i>Category: Government and/or Regulatory Authority</i>	

---

<b>M. Smith</b>	Rockwell Automation Canada Inc. Control Systems, Cambridge, Ontario <i>Category: Producer Interest</i>	
<b>A.Z. Tsisserev</b>	Applied Engineering Solutions Ltd., Vancouver, British Columbia <i>Category: General Interest</i>	
<b>M. Humphries</b>	CSA Group, Mississauga, Ontario	<i>Project Manager</i>

# ***Subcommittee on Meter-Mounting Devices***

<b>S. Michaud</b>	Thomas & Betts Limited, Dorval, Québec	<i>Chair</i>
<b>M. Bernard</b>	Thomas & Betts Limited, St-Jean-sur-Richelieu, Québec	
<b>Y. Boodram</b>	Schneider Electric Canada, Inc., Mississauga, Ontario	
<b>M. DiLillo</b>	Thomas & Betts Limited, St-Jean-sur-Richelieu, Québec	
<b>T. Evans</b>	CSA Group, Toronto, Ontario	
<b>D. Généreux</b>	Hydro-Québec, Distribution, Montréal, Québec	
<b>R. Lapp</b>	Markham Hydro Electric Commission, Markham, Ontario	
<b>T. Lepera</b>	Tomco Electrical Innovation Inc, Niagara Falls, Ontario	
<b>G. Montminy</b>	Régie du bâtiment du Québec, Québec, Québec	
<b>A. Rocha</b>	Siemens Canada, Oakville, Ontario	
<b>C.J. Workman</b>	Eaton Industries (Canada) Company, Burlington, Ontario	
<b>A. Hawley</b>	CSA Group, Mississauga, Ontario	<i>Project Manager</i>

# Preface

This is the sixth edition of CSA C22.2 No. 115, *Meter-mounting devices*, one of a series of Standards issued by CSA Group under the *Canadian Electrical Code, Part II*. It supersedes the previous editions published in 1989, 1983, 1971, 1967, and 1963.

Changes to this edition include

- a) the addition of 320 A self-contained meter-mounting devices;
- b) the addition of requirements for bypass for self-contained meter-mount devices greater than 200 A; and
- c) updated reference publications.

For general information on the Standards of the *Canadian Electrical Code, Part II*, see the Preface of CAN/CSA-C22.2 No. 0, *General Requirements — Canadian Electrical Code, Part II*.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the Subcommittee on Meter-Mounting Devices under the jurisdiction of the Technical Committee on Industrial Products and the Strategic Steering Committee on Requirements for Electrical Safety.

**Interpretations:** The Strategic Steering Committee on Requirements for Electrical Safety has provided the following direction for the interpretation of standards under its jurisdiction: “The literal text shall be used in judging compliance of products with the safety requirements of this Standard. When the literal text cannot be applied to the product, such as for new materials or construction, and when a relevant committee interpretation has not already been published, CSA’s procedures for interpretation shall be followed to determine the intended safety principle.”

**Notes:**

- 1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- 2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the user of the Standard to judge its suitability for his particular purpose.*
- 3) *This Standard was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this Standard.*
- 4) *To submit a request for interpretation of this Standard, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Request for interpretation” in the subject line:*
  - a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
  - b) *provide an explanation of circumstances surrounding the actual field condition; and*
  - c) *where possible, phrase the request in such a way that a specific “yes” or “no” answer will address the issue.*

*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are available on the Current Standards Activities page at [standardsactivities.csa.ca](http://standardsactivities.csa.ca).*
- 5) *This Standard is subject to review five years from the date of publication and suggestions for its improvement will be referred to the appropriate committee. To submit a proposal for change, please send the following information to [inquiries@csagroup.org](mailto:inquiries@csagroup.org) and include “Proposal for change” in the subject line:*
  - a) *Standard designation (number);*
  - b) *relevant clause, table, and/or figure number;*
  - c) *wording of the proposed change; and*

d) *rationale for the change.*

# CSA C22.2 No. 115:14

## *Meter-mounting devices*

### 1 Scope

#### 1.1

This Standard applies to indoor and outdoor meter-mounting devices, either as complete self-contained devices or provided as a part of service equipment, for use in nonhazardous locations, and intended to be employed in accordance with the Rules of the *Canadian Electrical Code, Part I* (“CEC Part I”).

#### 1.2

This Standard covers devices for use with watt hour meters, demand meters, time switches, current transformers, test switches, instruments, and similar devices rated at 320 A or less per meter socket, 600 V or less, single or polyphase, and multiple-position meter socket assemblies with an overall current rating of 600 A or less (200 A maximum per meter socket).

#### 1.3

This Standard applies to subfeed meter-mounting devices that have provision for the main load terminations and for one subfeed termination.

#### 1.4

This Standard applies to the meter-mounting device portion when supplied as a part of service or other equipment where applicable.

#### 1.5

Meter-mounting devices, as covered by this Standard, are not intended to be used as load-making or load-breaking devices.

#### 1.6

This Standard applies to transformer-rated meter-mounting devices that consist of current transformers, meter sockets, and optional test switches, mounted in the same enclosure rated 600 A or less and 600 V (nominal) or less.

#### 1.7

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; and “may” is used to express an option or that which is permissible within the limits of the standard.

Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material.

Notes to tables and figures are considered part of the table or figure and may be written as requirements.