



STANDARD

ANSI/ASHRAE Standard 63.2-2017
(Supersedes ANSI/ASHRAE Standard 63.2-1996)

Method of Testing Liquid-Line Filter Drier Filtration Capability

Approved by ASHRAE on May 31, 2017, and by the American National Standards Institute on June 1, 2017.

ASHRAE Standards are scheduled to be updated on a five-year cycle; the date following the Standard number is the year of ASHRAE approval. The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide) or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2017 ASHRAE

ISSN 1041-2336



ASHRAE Standard Project Committee 63.2
Cognizant TC: 3.3, Refrigerant Contaminant Control
SPLS Liaison: Peter Simmonds

Glen L. Steinkoenig*, *Chair*
Corey Anderson*
Michael D. Ditello*

Juan M. Flores*
Zidu Ma*
Julie Majurin*

Christopher Reeves
Stephen V. Spletzer*
Scott S. Wujek*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2016–2017

Rita M. Harrold, *Chair*
Steven J. Emmerich, *Vice-Chair*
James D. Aswegan
Niels Bidstrup
Donald M. Brundage
Drury B. Crawley
John F. Dunlap,
James W. Earley, Jr.
Keith I. Emerson
Julie M. Ferguson

Michael W. Gallagher
Walter T. Grondzik
Vinod P. Gupta
Susanna S. Hanson
Roger L. Hedrick
Rick M. Heiden
Srinivas Katipamula
Cesar L. Lim
Arsen K. Melikov
R. Lee Millies, Jr.

Cyrus H. Nasser
David Robin
Peter Simmonds
Dennis A. Stanke
Wayne H. Stoppelmoor, Jr.
Jack H. Zarour
William F. Walter, *BOD ExO*
Patricia Graef, *CO*

Stephanie C. Reiniche, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as "substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution." Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- a. interpretation of the contents of this Standard,
- b. participation in the next review of the Standard,
- c. offering constructive criticism for improving the Standard, or
- d. permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

CONTENTS
ANSI/ASHRAE Standard 63.2-2017
Method of Testing Liquid-Line Filter Drier Filtration Capability

SECTION	PAGE
Foreword	2
1 Purpose	2
2 Scope	2
3 Definitions.....	2
4 Materials and Apparatus	2
5 Test to Determine Accuracy of Test System	4
6 Procedure.....	4
7 Calculation of Results.....	5
Informative Annex A: Sample Calculation	6
Informative Annex B: Bibliography	7

NOTE

Approved addenda, errata, or interpretations for this standard can be downloaded free of charge from the ASHRAE website at www.ashrae.org/technology.

© 2017 ASHRAE

1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org · All rights reserved.

ASHRAE is a registered trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
ANSI is a registered trademark of the American National Standards Institute.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objections on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

ASHRAE Standard 63.2 prescribes a method for measuring the filtration capability of liquid-line filters and filter driers for use in refrigerant systems.

It is recognized that the test contaminant, the test fluid, the test equipment, and the method in the prescribed test do not fully represent the conditions that can exist in the liquid line of a refrigerant system.

The specified test contaminant was chosen as the most nearly representative controlled-particle-size test contaminant commercially available. The wide range of controlled particle sizes used provides a satisfactory degree of repeatability of test results. However, it is recognized that seldom, if ever, will the composition, particle size, and mix of the test contaminant be duplicated in an actual system. Therefore, the filtration capability of a filter determined by this test does not necessarily predict its exact capability in actual service in a refrigerant liquid line.

This test, however, serves as a useful means of comparing filter capabilities and implementing quality control to maintain uniformity of products.

Changes in the 2017 edition of the standard include improvements to the clarity of the test procedure and associated calculations and the addition of test fluid options.

1. PURPOSE

The purpose of this standard is to prescribe a laboratory test method for evaluating the filtration capability of filters and filter driers used in liquid lines of refrigeration systems.

2. SCOPE

2.1 This laboratory test method evaluates the capability of liquid-line filters and filter driers only for removing and retaining solid particles of a standard test contaminant.

2.2 The test method may be applied to all hermetic refrigerant liquid-line filters and filter driers.

2.3 The technique employed in this standard is the one-pass test method. In this test, a clean-up filter is installed downstream of the test sample and is designed to retain and prevent recirculation of the majority of the contaminant particles that are not collected by the test sample in the first pass.

2.4 Filter driers have the added capability of removing and retaining certain dissolved contaminants. This standard does not provide measurement of this capability.

3. DEFINITIONS

clean-up filter loading (M_{cf}): mass in grams of test contaminant that is retained on the clean-up filter.

contaminant capacity (M_c): mass in grams of test contaminant that is retained by the filter under test.

contaminant loading (M_l): total mass in grams of test contaminant that is added to the test apparatus.

contaminant loading end point (M_e): total mass in grams of test contaminant added that achieved the target end-point pressure drop

end-point pressure drop: the filter pressure drop across the filter under test at the concluding point of the testing.

filter efficiency (E_f): contaminant capacity divided by contaminant loading, expressed as a percent.

filter pressure drop (ΔP): the difference in pressure between the filter inlet and filter outlet, including fittings, expressed in kilopascals.

filter under test: liquid-line filter or liquid-line filter drier that is under evaluation.

liquid-line filter: a device for removing and retaining solid contaminants from the liquid line of a refrigeration system.

liquid-line filter drier: a filter containing a desiccant capable of removing moisture and other dissolved contaminants in the refrigerant stream.

test flow rate: the flow of clean test fluid, expressed in kilograms per second, that is specified for the filter under test.

4. MATERIALS AND APPARATUS

4.1 Test Contaminant

4.1.1 Composition. The test contaminant will be a blend of 50% coarse test dust as received and 50% retained in a 200-mesh screen. Prepare this blend from Society of Automotive Engineers (SAE) coarse test dust, described in ISO 5011.

4.1.2 Preparation of Test Contaminant. To prepare the blend of contaminant, first wet-screen a quantity of coarse test dust on a U.S. (ASTM) or Tyler 200-mesh screen with particle retention equal to 74 μm (0.0029 in.). This is done by placing a portion of the coarse test dust on a 200-mesh screen and running water through the screen while stirring the coarse test dust with the fingers. Discard the fine particles passing through the screen.

The +200-mesh particles collected on the screen are removed and dried for one hour at 110°C (230°F). The test contaminant is prepared by mixing 50% by mass of the coarse test dust as received (after drying for one hour at 110°C) with 50% by mass of the +200-mesh-screened dust.

4.1.2.1 Particle Size Analysis. The coarse test dust as received and the blend used as the test contaminant have the particle sizes listed in Table 1.

4.2 Test Fluid. Permissible test fluids are shown in Table 2. Take appropriate steps to minimize evaporation or loss of test fluid during the test procedure.

4.3 Clean-Up Filter. The clean-up filter shall be a filter membrane of 0.8 μm (3.15×10^{-5} in.) pore size. The filter is used to determine the amount of contaminant that passed through the filter under test.