



**ASME A112.19.3-2008/
CSA B45.4-08**

Stainless steel plumbing fixtures



Legal Notice for Harmonized Standard Jointly Developed by ASME and CSA

Intellectual property rights and ownership

As between American Society of Mechanical Engineers ("ASME") and Canadian Standards Association ("CSA") (collectively "ASME and CSA") and the users of this document (whether it be in printed or electronic form), ASME and CSA are the joint owners of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. The unauthorized use, modification, copying, or disclosure of this document may violate laws that protect the intellectual property of ASME and CSA and may give rise to a right in ASME and CSA to seek legal redress for such use, modification, copying, or disclosure. ASME and CSA reserve all intellectual property rights in this document.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document's fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party's intellectual property rights. ASME and CSA do not warrant the accuracy, completeness, or currency of any of the information published in this document. ASME and CSA make no representations or warranties regarding this document's compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL ASME AND CSA, THEIR RESPECTIVE VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF ASME OR CSA HAVE BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, ASME and CSA are not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and ASME and CSA accept no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

ASME and CSA have no power, nor do they undertake, to enforce compliance with the contents of the standards or other documents they jointly publish.

Authorized use of this document

This document is being provided by ASME and CSA for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by ASME and CSA to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from ASME and CSA; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Update No. 2

ASME A112.19.3-2008/CSA B45.4-08

March 2011

Note: General Instructions for CSA Standards are now called Updates. Please contact CSA Information Products Sales or visit www.ShopCSA.ca for information about the **CSA Standards Update Service**.

Title: *Stainless steel plumbing fixtures* — originally published August 2008

Revisions issued: Update No. 1 — July 2009

If you are missing any updates, please contact CSA Information Products Sales or visit www.ShopCSA.ca.

The following revisions have been formally approved and are marked by the symbol delta (Δ) in the margin on the attached replacement pages:

Revised	Clause 4.8.3
New	None
Deleted	Clauses 4.8.3.1 and 4.8.3.2

ASME A112.19.3-2008/CSA B45.4-08 originally consisted of **30 pages** (xii preliminary and 18 text), each dated **August 2008**. It now consists of the following pages:

August 2008	iii–xii, 3, 4, and 7–18
July 2009	1 and 2
March 2011	5 and 6

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.

ASME



J5008B

INTENTIONALLY LEFT BLANK

4.4 Waste fitting openings, drainage, and overflows

4.4.1 Waste fitting openings and drainage

4.4.1.1

Fixtures shall

- (a) have a waste fitting opening (outlet), the centre of which shall be located at the lowest point of the fixture; and
- (b) drain to the waste outlet.

4.4.1.2

Except when proprietary (i.e., non-standard) waste fittings are provided by the manufacturer, the dimensions of waste outlets shall be as shown in Figure 1.

4.4.1.3

Factory-supplied waste fittings shall comply with ASME A112.18.2/CAN/CSA-B125.2.

4.4.2 Overflows

4.4.2.1 Provision and positioning

Overflows in lavatories, sinks, and bidets may be provided at the option of the manufacturer. When overflows are provided, the manner in which they are positioned shall be at the option of the manufacturer.

4.4.2.2 Cleaning

When provided, overflows in sinks intended for food preparation (e.g., kitchen and bar sinks) shall not be concealed and shall be accessible for disassembly and cleaning after installation.

4.5 Additional requirements for water closets

Water closets and their flushing devices shall comply with the applicable requirements of ASME A112.19.2/CSA B45.1, except that the

- (a) structural integrity test shall be conducted in accordance with Clause 5.5.1; and
- (b) minimum thickness requirements for vitreous china shall not apply.

4.6 Additional requirements for urinals

Urinals and their flushing devices shall comply with the applicable requirements of ASME A112.19.2/CSA B45.1, except that the

- (a) structural integrity test shall be conducted in accordance with Clause 5.5.3; and
- (b) minimum thickness requirements for vitreous china shall not apply.

4.7 Additional requirements for lavatories, sinks, and bidets

4.7.1 Openings and mounting surfaces for supply fittings

4.7.1.1

When provided, openings and mounting surfaces for lavatory, sink, and bidet supply fittings shall be as shown in Figures 2 to 6, except when proprietary (i.e., non-standard) supply fittings are provided by the manufacturer.

4.7.1.2

Factory-supplied lavatory, sink, and bidet supply fittings shall comply with ASME A112.18.1/CAN/CSA-B125.1.

4.7.1.3

Mounting surfaces for supply fittings that rely on an air gap for backflow protection shall be not more than 13 mm (0.5 in) below the flood level rim.

Note: Care should be taken to ensure that the minimum air gap specified in ASME A112.18.1/CAN/CSA-B125.1 or in the applicable plumbing code is not compromised when supply fittings are installed on fixtures with mounting surfaces below the flood level rim.

4.7.2 Laundry or utility sink capacity

The minimum capacity of at least one compartment of a laundry or utility sink shall be 60 L (15.9 gal).

4.8 Additional requirements for bathtubs and shower bases

4.8.1 Minimum dimensions for bathtubs

The minimum dimensions for bathtubs shall be as shown in Figure 7.

4.8.2 Slope to the waste outlet

Bathtubs and shower bases shall have a maximum slope of 4% to the waste outlet.

Note: There should be a minimum slope of 1% to the waste outlet.

Δ 4.8.3 Flanges

Bathtubs and shower bases intended for installation against a wall shall incorporate a flange raised at least 8 mm (0.3 in) above the rim. The flange shall be

- (a) integral with the bathtub or shower base;
- (b) added to an island tub or shower base in the factory; or
- (c) field installed using a flange kit that complies with Clause 5.3 and includes all necessary parts and fasteners.

Fixtures using field-installed flanges shall be marked in accordance with Clause 6.4.

Note: Flanges are also referred to as beads.

4.9 Additional requirements for drinking fountains

4.9.1

Drinking fountains shall

- (a) include a supply fitting, which shall be at least 25 mm (1.0 in) above the flood level rim; and
- (b) comply with the dimensions shown in Figure 8.

Note: Drinking fountain supply fittings are also known as drinking fountain bubblers.

4.9.2

Factory-supplied drinking fountain supply fittings shall comply with ASME A112.18.1/CAN/CSA-B125.1, including the toxicity requirements.

4.10 Accessible design fixtures

Fixtures designed to be accessible shall comply with the dimensional requirements specified in CAN/CSA-B651 or ICC/ANSI A117.1.

Update No. 1

ASME A112.19.3-2008/CSA B45.4-08

July 2009

Note: *General Instructions for CSA Standards are now called Updates. Please contact CSA Information Products Sales or visit www.ShopCSA.ca for information about the **CSA Standards Update Service**.*

Title: *Stainless steel plumbing fixtures* — originally published August 2008

The following revisions have been formally approved and are marked by the symbol delta (Δ) in the margin on the attached replacement pages:

Revised	Clause 1.2
New	None
Deleted	None

ASME A112.19.3-2008/CSA B45.4-08 originally consisted of **30 pages** (xii preliminary and 18 text), each dated **August 2008**. It now consists of the following pages:

August 2008	iii–xii and 3–18
July 2009	1 and 2

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.

ASME A112.19.3-2008/CSA B45.4-08

Stainless steel plumbing fixtures

0 Introduction

0.1

This harmonized Standard was developed in response to an industry request for a Standard for evaluation of plumbing fixtures that would be acceptable for use in both Canada and the United States. Harmonized Standards for plumbing fixtures made of other materials are also available or under development.

0.2

The concept of harmonization for plumbing fixtures arose in the early 1990s, when a free trade agreement between Canada, Mexico, and the United States began to be discussed. Standards development organizations (SDOs) were at the forefront of these discussions and an opportunity soon arose for those SDOs involved in developing requirements for plumbing products to establish a process for harmonization. However, the effort to develop a trinational Standard stalled until 2001, when ASME and CSA decided to develop a binational Standard for plumbing fittings.

0.3

Harmonization activities for plumbing fixtures standards were undertaken in 2004 by a Joint Harmonization Task Group (JHTG) on Plumbing Fixtures, in which the ASME and CSA plumbing fixtures committees were equally represented. The responsibility for procedural matters and final approval of technical content was assumed by technical committees at higher levels within each SDO.

1 Scope

1.1

This Standard covers plumbing fixtures made of stainless steel alloys and specifies requirements for materials, construction, performance, testing, and markings.

Note: The term "corrosion-resisting steel" is also applied to stainless steel.

Δ 1.2

This Standard covers the following plumbing fixtures:

- (a) bathtubs;
- (b) bidets;
- (c) drinking fountains and water coolers;
- (d) lavatories;
- (e) shower bases;
- (f) sinks:
 - (i) kitchen and bar sinks;
 - (ii) laboratory sinks;
 - (iii) laundry sinks;
 - (iv) service sinks; and
 - (v) utility sinks;
- (g) urinals; and
- (h) water closets.

1.3

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; “may” is used to express an option or that which is permissible within the limits of the standard; and “can” is used to express possibility or capability. Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material. Notes to tables and figures are considered part of the table or figure and may be written as requirements. Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

1.4

SI units are the units of record in Canada. In this Standard, the yard/pound units are shown in parentheses. The values stated in each measurement system are equivalent in application; however, each system is to be used independently. Combining values from the two measurement systems can result in non-conformance with this Standard.

All references to gallons are to U.S. gallons.

For information on the unit conversion criteria used in this Standard, see Annex A.

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

CSA (Canadian Standards Association)

CAN/CSA-B125.3-05

Plumbing fittings

CAN/CSA-B651-04

Accessible design for the built environment

C22.2 No. 0.15-01 (R2006)

Adhesive labels

ASME/CSA (American Society of Mechanical Engineers/Canadian Standards Association)

ASME A112.18.1-2005/CAN/CSA-B125.1-05

Plumbing supply fittings

ASME A112.18.2-2005/CAN/CSA-B125.2-05

Plumbing waste fittings

ASME A112.19.2-2008/CSA B45.1-08

Ceramic plumbing fixtures

ASTM International (American Society for Testing and Materials)

A 240/A 240M-08

Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications

ICC/ANSI (International Code Council/American National Standards Institute)

A117.1-2003

Accessible and Usable Buildings and Facilities

CSA Standards Update Service

ASME A112.19.3-2008/CSA B45.4-08

August 2008

Title: *Stainless steel plumbing fixtures*

Pagination: **30 pages** (xii preliminary and 18 text), each dated **August 2008**

To register for e-mail notification about any updates to this publication

- go to **www.ShopCSA.ca**
- click on **E-mail Services** under **MY ACCOUNT**
- click on **CSA Standards Update Service**

The **List ID** that you will need to register for updates to this publication is **2019163**.

If you require assistance, please e-mail techsupport@csa.ca or call 416-747-2233.

Visit CSA's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

ASME/CSA Standard

ASME A112.19.3-2008/CSA B45.4-08
Stainless steel plumbing fixtures



[®]Registered trade-mark of Canadian Standards Association

Commitment for Amendments

This Standard is issued jointly by The American Society of Mechanical Engineers (ASME) and the Canadian Standards Association (CSA). Amendments to this Standard will be made only after processing according to the Standards writing procedures of both ASME and CSA.

The American Society of Mechanical
Engineers (ASME)
Three Park Avenue
New York, NY 10016-5990
USA
www.asme.org

ISBN-13: 978-0-7918-3173-1
ISBN-10: 0-7918-3173-6

© Copyright 2008

The 2008 edition of this Standard is being issued with an automatic addenda subscription service. The use of addenda allows revisions made in response to public review comments or committee actions to be published as necessary.

Published in August 2008 by Canadian
Standards Association
A not-for-profit private sector organization
5060 Spectrum Way, Suite 100
Mississauga, Ontario, Canada
L4W 5N6
1-800-463-6727 • 416-747-4044
Visit the CSA Online Store at www.ShopCSA.ca

ISBN 978-1-55436-506-7

Technical Editor: Abraham I. Murra

© Canadian Standards Association — 2008

All rights reserved. No part of this publication may be reproduced in any form whatsoever without the prior permission of the publisher.

Contents

ASME Standards Committee on Plumbing Materials and Equipment v

ASME Project Team 19.3 — Stainless Steel Plumbing Fixtures vii

CSA Technical Committee on Plumbing Fixtures viii

ASME/CSA Joint Harmonization Task Group on Plumbing Fixtures x

Preface xi

0 Introduction 1

1 Scope 1

2 Reference publications 2

3 Definitions 3

4 General requirements 4

4.1 Materials 4

4.2 Stainless steel thickness 4

4.2.1 Lavatories and sinks 4

4.2.2 Other fixtures 4

4.3 Tolerances 4

4.4 Waste fitting openings, drainage, and overflows 5

4.4.1 Waste fitting openings and drainage 5

4.4.2 Overflows 5

4.5 Additional requirements for water closets 5

4.6 Additional requirements for urinals 5

4.7 Additional requirements for lavatories, sinks, and bidets 5

4.7.1 Openings and mounting surfaces for supply fittings 5

4.7.2 Laundry or utility sink capacity 6

4.8 Additional requirements for bathtubs and shower bases 6

4.8.1 Minimum dimensions for bathtubs 6

4.8.2 Slope to the waste outlet 6

4.8.3 Flanges 6

4.9 Additional requirements for drinking fountains 6

4.10 Accessible design fixtures 6

5 Tests 7

5.1 Surface examination 7

5.1.1 Procedure 7

5.1.2 Performance 7

5.2 Warpage test 7

5.2.1 Procedure 7

5.2.2 Performance 7

5.3 Field-installed flange test 7

5.3.1 Procedure 7

5.3.2 Performance 7

5.4 Overflow test 8

5.4.1 Procedure 8

- 5.4.2 Performance 8
- 5.5 Structural integrity tests 8
 - 5.5.1 Water closets 8
 - 5.5.2 Lavatories and sinks 8
 - 5.5.3 Wall-mounted urinals 9
 - 5.5.4 Bathtubs and shower bases 9

6 Markings, packaging, and installation instructions and other literature 10

- 6.1 General 10
- 6.2 Non-standard fixtures 11
- 6.3 Additional markings for water closets and urinals 11
- 6.4 Field-installed flanges 11
- 6.5 Packaging and installation instructions and other literature 11
 - 6.5.1 General 11
 - 6.5.2 Packaging 11
 - 6.5.3 Installation instructions 12

Annexes

- A** (informative) — Unit conversion criteria 18

Tables

- 1** — Thickness of stainless steel sheet, mm (in) 12

Figures

- 1** — Waste outlet dimensions 13
- 2** — Opening and mounting surface dimensions for standard 200 mm (8 in) deck fittings 14
- 3** — Opening and mounting surface dimensions for standard 200 mm (8 in) combination fittings 14
- 4** — Opening and mounting surface dimensions for standard 100 mm (4 in) centre-set fittings 15
- 5** — Opening and mounting surface dimensions for standard 200 mm (8 in) combination fittings 15
- 6** — Opening and mounting surface dimensions for single-mount supply fittings 16
- 7** — Dimensions for bathtubs 16
- 8** — Clearance for drinking fountains 17

ASME Standards Committee on Plumbing Materials and Equipment

D.W. Viola	IAPMO, Mokena, Illinois, USA	<i>Chair</i>
S.A. Remedios	Delta Faucet Company, Indianapolis, Indiana, USA	<i>Vice-Chair</i>
R.H. Ackroyd	Rand Engineering, Newburyport, Massachusetts, USA	
S.F. Aridi	NSF International, Ann Arbor, Michigan, USA	
J.A. Ballanco	JB Engineering & Code Consulting, PC, Munster, Indiana, USA	
J. Bouwer	Euro Sales Inc., Elora, Ontario	
M.N. Burgess	Burgess Group Incorporated, San Diego, California, USA	
M. Campos	IAPMO, Ontario, California, USA	
S.L. Cavanaugh	Cavanaugh Consulting, Burbank, California, USA	
P.V. DeMarco	American Standard Inc., Piscataway, New Jersey, USA	
G.S. Duren	Code Compliance Inc., Keystone Heights, Florida, USA	
A.R. Emmerson	Buffalo Grove, Illinois, USA	
L.S. Galowin	Bethesda, Maryland, USA	
R.I. Greenwald	Dover, Delaware, USA	
D.E. Holloway	IAPMO Testing & Services, Tulsa, Oklahoma, USA	
J.M. Koeller	Koeller and Company, Yorba Linda, California, USA	
N.M. Kummerlen	Moen Incorporated, North Olmsted, Ohio, USA	
J.W. Lauer	Sloan Valve Company, Franklin Park, Illinois, USA	

R.M. Martin	California Energy Commission, Sacramento, California, USA	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	
G.L. Simmons	Charlotte Pipe and Foundry Co., Charlotte, North Carolina, USA	
W.M. Smith	Jay R. Smith Mfg. Co., Montgomery, Alabama, USA	
F.R. Volgstadt	Volgstadt & Associates Inc., Madison, Ohio, USA	
R.E. White	Richard E. White & Associates, South Bend, Indiana, USA	
W.C. Whitehead	Whitehead Consulting Services, Danvers, Massachusetts, USA	
C.J. Gomez	ASME, New York, New York, USA	<i>Secretary</i>

ASME Project Team 19.3 — Stainless Steel Plumbing Fixtures

D.E. Holloway	IAPMO Testing & Services, Tulsa, Oklahoma, USA	<i>Chair</i>
R. Brown	Franke Kindred Canada Limited, Midland, Ontario	
M. Campos	IAPMO, Ontario, California, USA	
P.V. DeMarco	American Standard Inc., Piscataway, New Jersey, USA	
K. Fromme	Bradley Corporation, Menomonee Falls, Wisconsin, USA	
L.S. Galowin	Bethesda, Maryland, USA	
E. Ho	IAPMO Research & Testing, Inc., Markham, Ontario	
N.M. Kummerlen	Moen Incorporated, North Olmsted, Ohio, USA	
R.B. Martin	Intertech Corporation, Birmingham, Michigan, USA	
L.A. Mercer	Moen Incorporated, North Olmsted, Ohio, USA	
W.J. Moran	Elkay Manufacturing Co., Broadview, Illinois, USA	
B. Pines	C & R Plumbing & Heating Incorporated, Shelby Township, Michigan, USA	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	
D.W. Viola	IAPMO, Mokena, Illinois, USA	

CSA Technical Committee on Plumbing Fixtures

P.V. DeMarco	American Standard Inc., Piscataway, New Jersey, USA	<i>Chair</i>
F. Lemieux	Health Canada, Ottawa, Ontario	<i>Vice-Chair</i>
R. Armstrong	City of Saint John, Saint John, New Brunswick	<i>Associate</i>
J. Bouwer	Euro Sales Inc., Elora, Ontario	
R. Brown	Franke Kindred Canada Limited, Midland, Ontario	
C. Caruana	CSA International, Toronto, Ontario	<i>Associate</i>
S.L. Cavanaugh	Cavanaugh Consulting, Burbank, California, USA	
I.W. Chang	Intertek, Coquitlam, British Columbia	<i>Associate</i>
R.B. Chauhan	National Research Council Canada, Ottawa, Ontario	
B.G. Diggins	MJS Mechanical Limited, Calgary, Alberta <i>Representing the Mechanical Contractors Association of Canada</i>	
T.D. Ellison	Canadian Water and Wastewater Association, Ottawa, Ontario	<i>Associate</i>
F. Fernández	TOTO USA Inc., Ontario, California, USA	
P. Georgopoulos	City of Toronto, Toronto, Ontario	
D. Gervais	City of Windsor, Windsor, Ontario <i>Representing the Ontario Plumbing Inspectors Association</i>	
R. Hildebrand	Regional Municipality of Waterloo, Kitchener, Ontario	
L. Himmelblau	Chicago Faucet Company, Des Plaines, Illinois, USA	<i>Associate</i>

E. Ho	IAPMO Research & Testing, Inc., Markham, Ontario	<i>Associate</i>
K.S. Hui	Ontario Ministry of Municipal Affairs and Housing, Toronto, Ontario	
M. Karasu	VitrA USA — EKOM, Suwanee, Georgia, USA	<i>Associate</i>
S. Kimmons	Water Matrix Incorporated, Woodbridge, Ontario	<i>Associate</i>
J.M. Koeller	Koeller and Company, Yorba Linda, California, USA	
N.M. Kummerlen	Moen Incorporated, North Olmsted, Ohio, USA	
B. Lagueux	Saint-Nicolas, Québec <i>Consumer Representative</i>	
M. Légaré	Régie du bâtiment du Québec, Québec, Québec	
J. Manente	Regional Municipality of Peel, Brampton, Ontario	<i>Associate</i>
R.B. Martin	Intertech Corporation, Birmingham, Michigan, USA	<i>Associate</i>
S. Martin	Plumbing Manufacturers Institute, Rolling Meadows, Illinois, USA	<i>Associate</i>
T.J. McCann	Department of National Defence, Ottawa, Ontario	
D.A. Myers	UA/MCA Joint Apprenticeship & Training Committee of NB Inc., Miramichi, New Brunswick	
G.R. Pleasance	Regional Municipality of Durham, Whitby, Ontario	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	
S.A. Remedios	Delta Faucet Company, Indianapolis, Indiana, USA	
S. Rouleau	MAAX Canada Inc., Ste-Marie de Beauce, Québec	
A.I. Murra	Canadian Standards Association, Mississauga, Ontario	<i>Project Manager</i>

ASME/CSA Joint Harmonization Task Group on Plumbing Fixtures

J. Bouwer	Euro Sales Inc., Elora, Ontario	<i>Co-chair</i>
P.V. DeMarco	American Standard Inc., Piscataway, New Jersey, USA	<i>Co-chair</i>
C. Caruana	CSA International, Toronto, Ontario	
I.W. Chang	Intertek, Coquitlam, British Columbia	
P. Georgopoulos	City of Toronto, Toronto, Ontario	
E. Ho	IAPMO Research & Testing, Inc., Markham, Ontario	
N.M. Kummerlen	Moen Incorporated, North Olmsted, Ohio, USA	
F. Lemieux	Health Canada, Ottawa, Ontario	
R.B. Martin	Intertech Corporation, Birmingham, Michigan, USA	
T.J. McCann	Department of National Defence, Ottawa, Ontario	
S. Rawalpindiwala	Kohler Co., Kohler, Wisconsin, USA	
S.A. Remedios	Delta Faucet Company, Indianapolis, Indiana, USA	
S. Rouleau	MAAX Canada Inc., Ste-Marie de Beauce, Québec	
A.I. Murra	Canadian Standards Association, Mississauga, Ontario	<i>Project Manager</i>

Preface

This is the first edition of ASME A112.19.3/CSA B45.4, *Stainless steel plumbing fixtures*.

This Standard replaces

- (a) CAN/CSA-B45.4-02, *Stainless Steel Plumbing Fixtures*; and
- (b) ASME A112.19.3-2000, *Stainless Steel Plumbing Fixtures (Designed for Residential Use)*.

This Standard is considered suitable for use for conformity assessment within the stated scope of the Standard.

This Standard was prepared by the ASME/CSA Joint Harmonization Task Group on Plumbing Fixtures, under the jurisdiction of the ASME Standards Committee on Plumbing Materials and Equipment and the CSA Technical Committee on Plumbing Fixtures. The CSA Technical Committee operates under the jurisdiction of the CSA Strategic Steering Committee on Water Management Products, Materials, and Systems. This Standard has been formally approved by the ASME Standards Committee and the CSA Technical Committee. This Standard was approved as an American National Standard by the American National Standards Institute on July 31, 2008.

August 2008

ASME Notes:

- (1) *This standard was developed under procedures accredited as meeting the criteria for American National Standards and it is an American National Standard. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed Standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.*
- (2) *ASME does not “approve,” “rate,” or “endorse” any item, construction, proprietary device, or activity.*
- (3) *ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assume any such liability. Users of a standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.*
- (4) *Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this standard.*
- (5) *ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.*
- (6) *ASME issues written replies to inquiries concerning interpretation of technical aspects of this Standard. All inquiries regarding this Standard, including requests for interpretations, should be addressed to:*
Secretary, A112 Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

A request for interpretation should be clear and unambiguous. The request should

- *cite the applicable edition of the Standard for which the interpretation is being requested.*
- *phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings, which are necessary to explain the question; however, they should not contain proprietary names or information.*

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee.

Interpretations are published on the ASME Web site under the Committee Pages at <http://cstools.asme.org/> as they are issued.

CSA Notes:

- (1) *Use of the singular does not exclude the plural (and vice versa) when the sense allows.*
- (2) *Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.*
- (3) *This publication was developed by consensus, which is defined by CSA Policy governing standardization — Code of good practice for standardization as “substantial agreement. Consensus implies much more than a simple majority, but not necessarily unanimity”. It is consistent with this definition that a member may be included in the Technical Committee list and yet not be in full agreement with all clauses of this publication.*
- (4) *CSA Standards are subject to periodic review, and suggestions for their improvement will be referred to the appropriate committee.*
- (5) *All enquiries regarding this Standard, including requests for interpretation, should be addressed to Canadian Standards Association, 5060 Spectrum Way, Suite 100, Mississauga, Ontario, Canada L4W 5N6.
Requests for interpretation should
 - (a) *define the problem, making reference to the specific clause, and, where appropriate, include an illustrative sketch;*
 - (b) *provide an explanation of circumstances surrounding the actual field condition; and*
 - (c) *be phrased where possible to permit a specific “yes” or “no” answer.*Committee interpretations are processed in accordance with the CSA Directives and guidelines governing standardization and are published in CSA’s periodical Info Update, which is available on the CSA Web site at www.csa.ca.*
- (6) *Attention is drawn to the possibility that some of the elements of this Standard may be the subject of patent rights. CSA is not to be held responsible for identifying any or all such patent rights. Users of this Standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.*

ASME A112.19.3-2008/CSA B45.4-08

Stainless steel plumbing fixtures

0 Introduction

0.1

This harmonized Standard was developed in response to an industry request for a Standard for evaluation of plumbing fixtures that would be acceptable for use in both Canada and the United States. Harmonized Standards for plumbing fixtures made of other materials are also available or under development.

0.2

The concept of harmonization for plumbing fixtures arose in the early 1990s, when a free trade agreement between Canada, Mexico, and the United States began to be discussed. Standards development organizations (SDOs) were at the forefront of these discussions and an opportunity soon arose for those SDOs involved in developing requirements for plumbing products to establish a process for harmonization. However, the effort to develop a trinational Standard stalled until 2001, when ASME and CSA decided to develop a binational Standard for plumbing fittings.

0.3

Harmonization activities for plumbing fixtures standards were undertaken in 2004 by a Joint Harmonization Task Group (JHTG) on Plumbing Fixtures, in which the ASME and CSA plumbing fixtures committees were equally represented. The responsibility for procedural matters and final approval of technical content was assumed by technical committees at higher levels within each SDO.

1 Scope

1.1

This Standard covers plumbing fixtures made of stainless steel alloys and specifies requirements for materials, construction, performance, testing, and markings.

Note: The term "corrosion-resisting steel" is also applied to stainless steel.

1.2

This Standard covers the following plumbing fixtures:

- (a) bathtubs;
- (b) bidets;
- (c) drinking fountains and water coolers;
- (d) lavatories;
- (e) shower bases;
- (f) urinals; and
- (g) sinks:
 - (i) kitchen and bar sinks;
 - (ii) laboratory sinks;
 - (iii) laundry sinks;
 - (iv) service sinks; and
 - (v) utility sinks.

1.3

In this Standard, “shall” is used to express a requirement, i.e., a provision that the user is obliged to satisfy in order to comply with the standard; “should” is used to express a recommendation or that which is advised but not required; “may” is used to express an option or that which is permissible within the limits of the standard; and “can” is used to express possibility or capability. Notes accompanying clauses do not include requirements or alternative requirements; the purpose of a note accompanying a clause is to separate from the text explanatory or informative material. Notes to tables and figures are considered part of the table or figure and may be written as requirements. Annexes are designated normative (mandatory) or informative (non-mandatory) to define their application.

1.4

SI units are the units of record in Canada. In this Standard, the yard/pound units are shown in parentheses. The values stated in each measurement system are equivalent in application; however, each system is to be used independently. Combining values from the two measurement systems can result in non-conformance with this Standard.

All references to gallons are to U.S. gallons.

For information on the unit conversion criteria used in this Standard, see [Annex A](#).

2 Reference publications

This Standard refers to the following publications, and where such reference is made, it shall be to the edition listed below, including all amendments published thereto.

CSA (Canadian Standards Association)

CAN/CSA-B125.3-05

Plumbing fittings

CAN/CSA-B651-04

Accessible design for the built environment

C22.2 No. 0.15-01 (R2006)

Adhesive labels

ASME/CSA (American Society of Mechanical Engineers/Canadian Standards Association)

ASME A112.18.1-2005/CAN/CSA-B125.1-05

Plumbing supply fittings

ASME A112.18.2-2005/CAN/CSA-B125.2-05

Plumbing waste fittings

ASME A112.19.2-2008/CSA B45.1-08

Ceramic plumbing fixtures

ASTM International (American Society for Testing and Materials)

A 240/A 240M-08

Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications

ICC/ANSI (International Code Council/American National Standards Institute)

A117.1-2003

Accessible and Usable Buildings and Facilities

UL (Underwriters Laboratories Inc.)

969 (1995)

Standard for Marking and Labeling Systems

3 Definitions

The following definitions apply in this Standard:

Air gap — the unobstructed vertical distance, through the open atmosphere, between the lowest opening of a water supply and the flood level of the fixture.

Bidet — a fixture with a hot and cold water supply intended for genital and perineal hygiene.

Defect —

Blemish — a dent, depression, or raised portion on the visible stainless steel surface of a fixture.

Crack — a fracture in the surface or substrate material of a fixture.

Die mark — a visible scoring of the stainless steel surface of a fixture.

Pinhole — a hole in the stainless steel surface of a fixture whose largest dimension is 1.5 mm (0.06 in) or less.

Wrinkle — a corrugation in the stainless steel surface of a fixture that is visible or can be felt.

Fitting — a device that controls and guides the flow of water.

Note: See ASME A112.18.1/CAN/CSA-B125.1 and CAN/CSA-B125.3 for definitions of specific types of fittings.

Fixture — a device that receives water, waste matter, or both and directs these substances into a drainage system.

Note: See ASME A112.19.2/CSA B45.1 for definitions of specific types of fixtures.

Flange —

- (a) the flat area on the front or sides of a compartment in a sink or lavatory; or
- (b) the raised vertical section for retaining water in a tub or shower base.

Flat-rim sink (rim-back sink) — a single- or double-compartment sink with flanges on all sides but no back ledge (ledge-back).

Flood level — the level at which water will overflow a fixture.

Flushometer valve — a flushing device attached to a pressurized water supply pipe that, when actuated, opens the pipe for direct flow into the fixture at a rate and in a quantity that enables proper operation of the fixture. The valve then gradually closes to provide trap reseal in the fixture and avoid water hammer.

Note: The pipe to which the flushometer valve is connected should be large enough to enable it to deliver water at a sufficient rate of flow for flushing.

Horizontal surface — a surface forming an angle with the horizontal of less than 45°.

Integral rim — a mounting rim that is an integrally formed part of a sink flange and has clamp-down devices for attaching the sink to the countertop.

Lavatory — a washbowl or basin.

Ledge — the flat area of a sink or lavatory on which supply fittings are normally mounted.

Ledge-back sink — a single- or double-compartment sink with a ledge along the back that has openings for mounting supply fittings.