



Low-Voltage Fuses — Part 6: Class H Non-Renewable Fuses



Legal Notice for Standards

Canadian Standards Association (operating as “CSA Group”) develops standards through a consensus standards development process approved by the Standards Council of Canada. This process brings together volunteers representing varied viewpoints and interests to achieve consensus and develop a standard. Although CSA Group administers the process and establishes rules to promote fairness in achieving consensus, it does not independently test, evaluate, or verify the content of standards.

Disclaimer and exclusion of liability

This document is provided without any representations, warranties, or conditions of any kind, express or implied, including, without limitation, implied warranties or conditions concerning this document’s fitness for a particular purpose or use, its merchantability, or its non-infringement of any third party’s intellectual property rights. CSA Group does not warrant the accuracy, completeness, or currency of any of the information published in this document. CSA Group makes no representations or warranties regarding this document’s compliance with any applicable statute, rule, or regulation.

IN NO EVENT SHALL CSA GROUP, ITS VOLUNTEERS, MEMBERS, SUBSIDIARIES, OR AFFILIATED COMPANIES, OR THEIR EMPLOYEES, DIRECTORS, OR OFFICERS, BE LIABLE FOR ANY DIRECT, INDIRECT, OR INCIDENTAL DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES, HOWSOEVER CAUSED, INCLUDING BUT NOT LIMITED TO SPECIAL OR CONSEQUENTIAL DAMAGES, LOST REVENUE, BUSINESS INTERRUPTION, LOST OR DAMAGED DATA, OR ANY OTHER COMMERCIAL OR ECONOMIC LOSS, WHETHER BASED IN CONTRACT, TORT (INCLUDING NEGLIGENCE), OR ANY OTHER THEORY OF LIABILITY, ARISING OUT OF OR RESULTING FROM ACCESS TO OR POSSESSION OR USE OF THIS DOCUMENT, EVEN IF CSA GROUP HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES, INJURY, LOSS, COSTS, OR EXPENSES.

In publishing and making this document available, CSA Group is not undertaking to render professional or other services for or on behalf of any person or entity or to perform any duty owed by any person or entity to another person or entity. The information in this document is directed to those who have the appropriate degree of experience to use and apply its contents, and CSA Group accepts no responsibility whatsoever arising in any way from any and all use of or reliance on the information contained in this document.

CSA Group is a private not-for-profit company that publishes voluntary standards and related documents. CSA Group has no power, nor does it undertake, to enforce compliance with the contents of the standards or other documents it publishes.

Intellectual property rights and ownership

As between CSA Group and the users of this document (whether it be in printed or electronic form), CSA Group is the owner, or the authorized licensee, of all works contained herein that are protected by copyright, all trade-marks (except as otherwise noted to the contrary), and all inventions and trade secrets that may be contained in this document, whether or not such inventions and trade secrets are protected by patents and applications for patents. Without limitation, the unauthorized use, modification, copying, or disclosure of this document may violate laws that protect CSA Group’s and/or others’ intellectual property and may give rise to a right in CSA Group and/or others to seek legal redress for such use, modification, copying, or disclosure. To the extent permitted by licence or by law, CSA Group reserves all intellectual property rights in this document.

Patent rights

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights. CSA Group shall not be held responsible for identifying any or all such patent rights. Users of this standard are expressly advised that determination of the validity of any such patent rights is entirely their own responsibility.

Authorized use of this document

This document is being provided by CSA Group for informational and non-commercial use only. The user of this document is authorized to do only the following:

If this document is in electronic form:

- load this document onto a computer for the sole purpose of reviewing it;
- search and browse this document; and
- print this document if it is in PDF format.

Limited copies of this document in print or paper form may be distributed only to persons who are authorized by CSA Group to have such copies, and only if this Legal Notice appears on each such copy.

In addition, users may not and may not permit others to

- alter this document in any way or remove this Legal Notice from the attached standard;
- sell this document without authorization from CSA Group; or
- make an electronic copy of this document.

If you do not agree with any of the terms and conditions contained in this Legal Notice, you may not load or use this document or make any copies of the contents hereof, and if you do make such copies, you are required to destroy them immediately. Use of this document constitutes your acceptance of the terms and conditions of this Legal Notice.



Update No. 3

CAN/CSA-C22.2 No. 248.6-00

August 2005

Note: General Instructions for CSA Standards are now called Updates. Please contact CSA Information Products Sales or visit www.ShopCSA.ca for information about the **CSA Standards Update Service**.

Title: *Low-Voltage Fuses — Part 6: Class H Non-Renewable Fuses* — originally published August 2000

Revisions issued: Update No. 2 — November 2004

If you are missing any updates, please contact CSA Information Products Sales or visit www.ShopCSA.ca.

The following revisions have been formally approved and are marked by a vertical line in the margin on the attached replacement pages:

Revised	Title page, copyright page, Contents, Preface, and Clauses 1 and 8.2.4
New	Clause 8.1
Deleted	Foreword (ANCE) and Foreword (UL)

CAN/CSA-C22.2 No. 248.6-00 originally consisted of **14 pages**, each dated **August 2000**. It now consists of the following pages:

August 2000	10–12
November 2004	Cover
August 2005	1–9 and 13–16

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.

Commitment for Amendments

This Standard is issued jointly by the National Association of Standardization and Certification of the Electrical Sector (ANCE), CSA International, and Underwriters Laboratories Incorporated (UL). Amendments to this Standard will be made only after processing according to the Standards writing procedures by ANCE, CSA, and UL.

Revisions of this Standard will be made by issuing revised or additional pages bearing their date of issue. A UL Standard is current only if it incorporates the most recently adopted revisions, all of which are itemized on the transmittal notice that accompanies the latest set of revised requirements.

**Copyright © 2000,
2005 ANCE**

Rights reserved in favor
of ANCE

ISBN 1-55324-236-X

**Copyright © 2000
Canadian Standards
Association**

All rights reserved. No
part of this publication
may be reproduced in
any form whatsoever
without the prior
permission of the
publisher.

ISBN 0-7629-0556-5

**Copyright © 1996,
2005
Underwriters
Laboratories Inc.**

Update No. 2

C22.2 No. 248.6-00

November 2004

Note: General Instructions for CSA Standards are now called Updates. Please contact CSA Information Products Sales or visit www.ShopCSA.ca for information about the **CSA Standards Update Service**.

Title: *Low-Voltage Fuses — Part 6: Class H Non-Renewable Fuses* — originally published August 2000

The following revisions have been formally approved:

Revised	Outside front cover, inside front cover, and title page
New	None
Deleted	None

CSA C22.2 No. 248.6-00 originally consisted of **16 pages** each dated **August 2000**. It now consists of the following pages:

August 2000	3–16
November 2004	Cover, title page, and copyright page

- Update your copy by inserting these revised pages.
- Keep the pages you remove for reference.

Canadian Standards Association (operating as “CSA Group”), under whose auspices this National Standard has been produced, was chartered in 1919 and accredited by the Standards Council of Canada to the National Standards system in 1973. It is a not-for-profit, nonstatutory, voluntary membership association engaged in standards development and certification activities.

CSA Group standards reflect a national consensus of producers and users — including manufacturers, consumers, retailers, unions and professional organizations, and governmental agencies. The standards are used widely by industry and commerce and often adopted by municipal, provincial, and federal governments in their regulations, particularly in the fields of health, safety, building and construction, and the environment.

Individuals, companies, and associations across Canada indicate their support for CSA Group’s standards development by volunteering their time and skills to Committee work and supporting CSA Group’s objectives through sustaining memberships. The more than 7000 committee volunteers and the 2000 sustaining memberships together form CSA Group’s total membership from which its Directors are chosen. Sustaining memberships represent a major source of income for CSA Group’s standards development activities.

CSA Group offers certification and testing services in support of and as an extension to its standards development activities. To ensure the integrity of its certification process, CSA Group regularly and continually audits and inspects products that bear the CSA Group Mark.

In addition to its head office and laboratory complex in Toronto, CSA Group has regional branch offices in major centres across Canada and inspection and testing agencies in eight countries. Since 1919, CSA Group has developed the necessary expertise to meet its corporate mission: CSA Group is an independent service organization whose mission is to provide an open and effective forum for activities facilitating the exchange of goods and services through the use of standards, certification and related services to meet national and international needs.

For further information on CSA Group services, write to
CSA Group
178 Rexdale Boulevard
Toronto, Ontario, M9W 1R3
Canada



Standards Council of Canada
Conseil canadien des normes

A National Standard of Canada is a standard developed by a Standards Council of Canada (SCC) accredited Standards Development Organization, in compliance with requirements and guidance set out by SCC. More information on National Standards of Canada can be found at www.scc.ca.

SCC is a Crown corporation within the portfolio of Innovation, Science and Economic Development (ISED) Canada. With the goal of enhancing Canada's economic competitiveness and social well-being, SCC leads and facilitates the development and use of national and international standards. SCC also coordinates Canadian participation in standards development, and identifies strategies to advance Canadian standardization efforts.

Accreditation services are provided by SCC to various customers, including product certifiers, testing laboratories, and standards development organizations. A list of SCC programs and accredited bodies is publicly available at www.scc.ca.

Standards Council of Canada
600-55 Metcalfe Street
Ottawa, Ontario, K1P 6L5
Canada

Cette Norme Nationale du Canada est disponible en versions française et anglaise.

Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users to judge its suitability for their particular purpose.

®A trademark of the Canadian Standards Association, operating as “CSA Group”

National Standard of Canada

CSA C22.2 No. 248.6:00
Low-Voltage Fuses — Part 6: Class H
Non-Renewable Fuses



*®A trademark of the Canadian Standards Association,
operating as "CSA Group"*



ICS 29.120.50
ISBN 1-55324-236-X

**National Association of
Standardization and
Certification of the Electrical
Sector**

NMX-J-009/248/6-2000-ANCE
First Edition



Canadian Standards Association

CAN/CSA-C22.2 No. 248.6-00
Second Edition



**Underwriters Laboratories
Inc.**

UL 248-6
Second Edition



Low-Voltage Fuses – Part 6: Class H Non-Renewable Fuses

August 1, 2000

(Title page reprinted: November 2004)

Approved
by
Standards Council
of Canada



(approved November 2004)

Commitment for Amendments

This Standard is issued jointly by the National Association of Standardization and Certification of the Electrical Sector (ANCE), CSA International, and Underwriters Laboratories Incorporated (UL). Amendments to this Standard will be made only after processing according to the Standards writing procedures by ANCE, CSA, and UL.

Revisions of this Standard will be made by issuing revised or additional pages bearing their date of issue. A UL Standard is current only if it incorporates the most recently adopted revisions, all of which are itemized on the transmittal notice that accompanies the latest set of revised requirements.

**Copyright © 2000
ANCE**

Rights reserved in favor
of ANCE

ISBN 1-55324-236-X

**Copyright © 2000
Canadian Standards
Association**

All rights reserved. No
part of this publication
may be reproduced in
any form whatsoever
without the prior
permission of the
publisher.

ISBN 0-7629-0556-5

**Copyright © 1996,
2000
Underwriters
Laboratories Inc.**

(Copyright page replaced November 2004)

Standards Update Service

CSA C22.2 No. 248.6:00 August 2000

Title: *Low-Voltage Fuses — Part 6: Class H Non-Renewable Fuses*

To register for e-mail notification about any updates to this publication

- go to store.csagroup.org
- click on **Product Updates**

The **List ID** that you will need to register for updates to this publication is **2011329**.

If you require assistance, please e-mail techsupport@csagroup.org or call 416-747-2233.

Visit CSA Group's policy on privacy at www.csagroup.org/legal to find out how we protect your personal information.

**National Association of
Standardization and
Certification of the Electrical
Sector**

NMX-J-009/248/6-2000-ANCE
First Edition



CSA International
CSA C22.2 No. 248.6-00
Second Edition



**Underwriters Laboratories
Inc.**
UL 248-6
Second Edition



Low-Voltage Fuses – Part 6: Class H Non-Renewable Fuses

August 1, 2000

CONTENTS

Preface	4
1 General	9
1.1 Scope	9
4 Classification	9
5 Characteristics	9
5.2 Voltage rating	9
5.3 Current rating	9
5.5 Interrupting rating	10
6 Marking	10
6.1 Marking of fuses	10
7 Construction	10
7.1 Dimensions	10
8 Tests	13
8.1 Fuses for operation test	13
8.2 Verification of temperature rise and current-carrying capacity	13
8.3 Verification of overload operation	14
8.4 Verification of operation at rated voltage	14
9 Special Tests	14
9.1 General	14
9.2 Verification of low melting point "P" ("D" for time delay) characteristic	15

Preface

This is the common UL, CSA, and ANCE Standard for *Low-Voltage Fuses – Part 6: Class H Non-Renewable Fuses*. This is the second edition of CAN/CSA-C22.2 No. 248.6-00 (superseding the first edition, published in 1996), the second edition of UL 248-6, and the first edition of NMX-J-009/248/6-2000-ANCE.

This Standard was prepared by a Technical Harmonization Committee comprised of members from Underwriters Laboratories, CSA International, the National Association of Standardization and Certification of the Electrical Sector, the end product manufacturers, and material suppliers. The efforts and support of the members of the Technical Harmonization Committee are gratefully acknowledged.

The present Mexican Standard was developed by the TC 32 Fuses from the Comité de Normalización de la Asociación de Normalización y Certificación, A.C., CONANCE, with the collaboration of the fuse manufacturers and users.

This Standard was reviewed by the CSA Subcommittee on Fuses and approved by the Technical Committee on Industrial Products under the jurisdiction of the CSA Strategic Steering Committee on the Requirements for Electrical Safety.

This Standard has been approved by the American National Standards Institute (ANSI) as an American National Standard.

The most recent designation of ANSI/UL 248-6 as an American National Standard (ANSI) occurred on August 1, 2005.

This ANSI/UL Standard for Safety, which consists of the Second edition with revisions through August 11, 2005, is under continuous maintenance, whereby each revision is ANSI approved upon publication. Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <http://csds.ul.com>.

Note: Although the intended primary application of this Standard is stated in its Scope, it is important to note that it remains the responsibility of the users of the Standard to judge its suitability for their particular purpose.

Level of Harmonization

This trinational standard is published as an Identical Standard. An identical standard is a standard that is the same in technical content except for conflicts in Codes and Governmental Regulations. Presentation is word for word except for editorial changes.

Interpretations

The interpretation by the SDO (Standards Development Organization) of an identical standard shall be based on the literal text to determine compliance with the standard in accordance with the procedural rules of the SDO. If more than one interpretation of the literal text has been identified, a revision shall be proposed as soon as possible to each of the SDOs to more accurately reflect the intent.

ANCE Effective Date

The effective date for ANCE will be announced through the *Diario Oficial de la Federación (Official Gazette)* and is indicated on the cover page.

CSA Effective Date

The effective date for CSA will be announced through *CSA Informs* or *CSA Certification Notice*.

UL Effective Date

This edition of the standard is now in effect.

This page intentionally left blank.

Foreword (CSA)

The Canadian Standards Association (CSA) develops standards under the name Canadian Standards Association, and provides certification and testing under the name CSA International. CSA International provides certification services for manufacturers who, under license from CSA, wish to use the appropriate registered CSA Marks on certain products of their manufacture to indicate conformity with CSA Standards.

CSA Certification for a number of products is provided in the interest of maintaining agreed-upon standards of quality, performance, interchangeability and/or safety, as appropriate. Where applicable, certification may form the basis for acceptance by inspection authorities responsible for enforcement of regulations. Where feasible, programs will be developed for additional products for which certification is desired by producers, consumers, or other interests. In performing its functions in accordance with its objectives, CSA does not assume or undertake to discharge any responsibility of the manufacturer or any other party. The opinions and findings of the Association represent its professional judgement given with due consideration to the necessary limitations of practical operation and state of the art at the time the Standard is processed.

Products in substantial accord with this Standard but which exhibit a minor difference or a new feature may be deemed to meet the Standard providing the feature or difference is found acceptable utilizing appropriate CSA International Operating Procedures. Products that comply with this Standard shall not be certified if they are found to have additional features which are inconsistent with the intent of this Standard. Products shall not be certifiable if they are discovered to contravene applicable laws or regulations.

Testing techniques, test procedures, and instrumentation frequently must be prescribed by CSA International in addition to the technical requirements contained in Standards of CSA. In addition to markings specified in the Standard, CSA International may require special cautions, markings, and instructions that are not specified by the Standard.

Some tests required by CSA Standards may be inherently hazardous. The Association neither assumes nor accepts any responsibility for any injury or damage that may occur during or as the result of tests, wherever performed, whether performed in whole or in part by the manufacturer or the Association, and whether or not any equipment, facility, or personnel for or in connection with the test is furnished by the manufacturer or the Association.

Manufacturers should note that, in the event of the failure of CSA International to resolve an issue arising from the interpretation of requirements, there is an appeal procedure: the complainant should submit the matter, in writing, to the Secretary of the Canadian Standards Association.

If this Standard is to be used in obtaining CSA Certification please remember, when making application for certification, to request all current Amendments, Bulletins, Notices, and Technical Information Letters that may be applicable and for which there may be a nominal charge. For such information or for further information concerning CSA Certification, please address your inquiry to Applications and Customer Service, CSA International, 178 Rexdale Boulevard, Toronto, Ontario, Canada M9W 1R3.

Low-Voltage Fuses – Part 6: Class H Non-Renewable Fuses

1 General

NOTE –

This Part is intended to be read together with the Standard for Low-Voltage Fuses – Part 1: General Requirements, hereafter referred to as Part 1. The numbering of the Clauses in this Part correspond to like numbered Clauses in Part 1. The requirements of Part 1 apply unless modified by this Part. For Clauses not shown below, refer to the Standard for Low-Voltage Fuses – Part 1: General Requirements, NMX-J-009/248/6-2000-ANCE ♦ CAN/CSA C22.2 No. 248.1 ♦ UL 248-1.

1.1 Scope

This Part applies to Class H Non-Renewable fuses rated 600 A or less and either 250 or 600 V ac. DC ratings are optional.

4 Classification

Class H Non-Renewable fuses have an interrupting rating of 10,000 A. Both of the voltage ratings 250 V ac and 600 V ac are divided into six body sizes with the maximum current rating in each size as specified in this Part. These fuses are not classified as current limiting. Time-delay ratings are optional.

In Canada, 250 V ac fuses rated 15 – 60 A shall have a low melting point "P" ("D" for time delay) characteristic. See Clauses 6.1 and 9.2.

5 Characteristics

5.2 Voltage rating

For AC, the rating shall be 250 V ac or 600 V ac in accordance with dimensions shown in Figures A and B.

The DC voltage rating may be different from the AC rating.

5.3 Current rating

Refer to Figures A and B for range of current ratings in each body size for each voltage rating.