

Institute of Environmental Sciences and Technology

IEST-RP-CC012.4

Contamination Control Division
Recommended Practice 012.4

Considerations in Cleanroom Design



1827 Walden Office Square, Suite 400
Schaumburg, IL 60173
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: information@iest.org • Web: www.iest.org

This Recommended Practice was prepared by and is under the jurisdiction of Working Group 12 of the IEST Contamination Control Division (WG-CC012). The following WG voting members contributed to the revision of this edition of this Recommended Practice:

Wei Sun, WG-CC012 Chair, Engsysco, Inc.

Mark Camenzind, Consultant

Yitzhak Vanek, Persys Engineering, Inc.

Roger Diener, Analog Devices, Inc.

Koji Miyasaka, Kanomax USA Inc.

Mark Mohwinkel, 3M Company

Ahmad Soueid, HDR, Inc.

Matt Smyers, TSS, Inc.

R. Vijayakumar, AERFIL

Taguhi Arakelian, Jet Propulsion Laboratory

Tengfang (Tim) Xu, Pacific Gas and Electric

Copyright © 2023 by the Institute of Environmental Sciences and Technology

First printing, August 2023

ISBN: 978-1-937280-60-4 (Electronic format)

ISBN: 978-1-937280-59-8 (Print format)

PROPOSAL FOR IMPROVEMENT: The Working Groups of the Institute of Environmental Sciences and Technology are continually working on improvements to their Recommended Practices and Reference Documents. Suggestions from users of these documents are welcome. If you have a suggestion regarding this document, please use the online Proposal for Improvement form found on the IEST website at www.iest.org.

Institute of Environmental Sciences and Technology
1827 Walden Office Square, Suite 400
Schaumburg, IL 60173
Phone: (847) 981-0100 • Fax: (847) 981-4130
E-mail: information@iest.org • Web: www.iest.org

NOTICE AND DISCLAIMER: This Recommended Practice is published by the Institute of Environmental Sciences and Technology (IEST) to advance the technical and engineering sciences. Use of this document is entirely voluntary, and determination of its applicability and suitability for any particular use is solely the responsibility of the user. Use of this Recommended Practice does not imply any warranty or endorsement by IEST.

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among all persons participating in the development of this document.

IEST standards, recommended practices, and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and seeks out the views of persons who have an interest in the topic covered by this publication. While IEST administers the process to promote fairness in the development of consensus, the organization does not write the document and does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in IEST standards, recommended practices, and guideline publications.

IEST disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. IEST disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of the particular purposes or needs of users of the document. IEST does not guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, IEST is not undertaking to render professional or other services for or on behalf of any person or entity, nor is IEST undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

IEST has no power, nor does it undertake to police or enforce compliance with the contents of this document. IEST does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document should not be attributable to IEST and is solely the responsibility of the certifier or maker of the statement.

ABSTRACT OF KEY REVISION AREAS

WHAT IS IMPROVED

- Enhanced description about the “Integrity of Building Envelope and Interstitial Spaces to Prevent Insects/Pests Entry” in Section 4.3.12.
- Improved description on “Process-specific airflow patterns”.
- Revised language on “Wireless sensor”.
- Detail discussions about dedicated space for storing cleaning equipment, water for cleaning and waste drain, etc. were added for the “Design considerations for controlling contamination” in Section 5.9.1.
- Improved and more detail discussions on “Optimization of workflow/paths in existing cleanroom spaces”, “Design for facility disinfection” and “CFD” analysis.

WHAT IS NEW

- Added discussion on “Impacts to building pressurization control”.
- Added detail diagrams for 4 categories of airlocks: Cascading, sink, bubble and dual-compartment.
- Added “Design considerations for cleanroom entry and exit for personnel”.
- Added new discussion section on “Room pressurization strategy”.
- Detail discussion about grounding connections for wrist strap, footwear, work surfaces, metal walls and ceiling grids to avoid charging and ESD, impacts by RFI generator and ionizers, etc. were added in the “Grounding systems” in Section 5.16.
- Added more discussion on “Airflow turn-down and reset” to reflect new ISO 14644-4 (2022) standard.
- Added discussion section for “Cleanroom enclosure airtightness”.
- Added discussion on “Demand based airflow control” to reflect ISO 14644-4 (2022).
- In the Appendix C of “Cleanroom Modeling Approach”, a new terminology called “contaminant removal effectiveness” was added to reflect the new 14644-4 (2022) and 14644-16 (2019) modeling equations, this correctional factor can increase the predictability in estimation and calculation airflow rate.
- New discussion about ground filters, personnel grounding plan, ESD tester, etc. were added into the “Grounding systems” in Section 5.16.
- Many new references (articles, books and standards) were added in the Bibliography of Appendix E.

Considerations in Cleanroom Design

IEST-RP-CC012.4

CONTENTS

SECTION

1	SCOPE AND LIMITATIONS	7
2	REFERENCES.....	7
3	TERMS AND DEFINITIONS	10
4	PLANNING AND PROGRAMMING PROCEDURES.....	14
5	DESIGN REQUIREMENTS	29
6	CLEANROOM CONSTRUCTION PROTOCOL	74

FIGURES

FIGURE 1. CLEANROOM ENERGY END USE (EXAMPLE 1)	25
FIGURE 2. CLEANROOM ENERGY END USE (EXAMPLE 2)	25
FIGURE 3. UNIDIRECTIONAL AIRFLOW	29
FIGURE 4. NONUNIDIRECTIONAL AIRFLOW.	30
FIGURE 5. MIXED AIRFLOW	30
FIGURE 6. MODEL OF EXISTING ROOM.	35
FIGURE 7. THE PROPOSED MODIFIED ROOM.	36
FIGURE 8. MAKE-UP AIR UNIT WITH NO RETURN AIR.	39
FIGURE 9. MAKE-UP AIR UNIT WITH RETURN AIR.	39
FIGURE 10. MAKE-UP AIR UNIT WITH ADDITIONAL RECIRCULATION FAN UNIT(S).....	40
FIGURE 11. MAKE-UP AIR UNIT WITH ADDITIONAL RECIRCULATION AHU.....	40
FIGURE 12. MAKE-UP AIR UNIT WITH ADDITIONAL RECIRCULATION AHU AND RECIRCULATION FAN(S).	41
FIGURE 13. COMMON TYPES OF AIRLOCKS.	46
FIGURE 14. PRESSURIZATION OR DEPRESSURIZATION SCENARIOS	48
FIGURE 15. GRAPHICAL DEFINITION OF CRITERION CURVES SHOWN IN TABLE 5	58
FIGURE C1. EXAMPLE OF AN HVAC CONFIGURATION AND PARTICLE BALANCE IN A CLEANROOM.....	91
FIGURE D1. IN-SITU ISO CLASS 5 CLEANROOM AIR VELOCITIES AND AIR CHANGE RATES	94

TABLES

TABLE 1. CATEGORIES OF CONTAMINANTS.....	15
TABLE 2. REDUNDANCY LEVELS.....	21
TABLE 3. KEY CONSIDERATIONS FOR IMPROVING ENERGY EFFICIENCY IN CLEANROOMS.....	25
TABLE 4. TYPICAL AIRFLOW RANGES IN CLEANROOMS IN COMMON PRACTICES.	34

TABLE 5. RECOMMENDED MINIMUM PRESSURE DIFFERENTIAL ACROSS CLEANROOM ENVELOPE	49
TABLE 6. NUMERICAL DEFINITION OF CRITERION CURVES SHOWN IN FIGURE 11.	57
TABLE 7. APPLICATION AND INTERPRETATION OF CRITERION CURVES SHOWN IN FIGURE 15.	59

APPENDIXES

APPENDIX A—REVIEWING AND TESTING CONCEPTS.....	78
APPENDIX B—SAMPLE CLEANROOM CONSTRUCTION PROTOCOL	80
APPENDIX C—CLEANROOM MODELING APPROACH	91
APPENDIX D—(EXAMPLE) COMPARISON OF RECOMMENDED AND SURVEYED AIR CHANGE RATES FOR ISO CLASS 5 CLEANROOMS	94
APPENDIX E—BIBLIOGRAPHY	95

COPYING IS ILLEGAL

Considerations in Cleanroom Design

IEST-RP-CC012.4

1 SCOPE AND LIMITATIONS

1.1 Scope

This Recommended Practice (RP) makes recommendations regarding factors to consider in the design of cleanroom facilities. This discussion is limited to those environmental conditions that typically confront cleanroom designers and users.

1.2 Limitations

This RP is limited to the design of cleanroom facilities. Equipment design is not within the scope of this RP, nor does this RP address process or operational considerations, except as those considerations relate to cleanroom design.

This RP is intended to provide users with factors to consider for cleanroom design, but discussion of these factors is not intended to be all-inclusive. The specified ranges and recommended criteria are intended only to provide a framework. Specific process or other needs may dictate requirements beyond the scope of this document. This RP is not intended to supersede specific requirements established by a recognized national or international regulating body.

2 REFERENCES

The following publications were used in the preparation of this document or are considered critical to its content; their citation in no way represents an endorsement or recommendation.

The cited editions of these documents are incorporated into this RP to the extent specified herein. Subsequent revisions of these publications do not automatically supersede the cited editions. Users should investigate the applicability of revised editions of the references.

2.1 FM Global

Cleanroom Materials Flammability Test Protocol (Class 4910) October 2013

2.2 Food and Drug Administration (FDA)

Guidance for Industry: Sterile Drug Products Produced by Aseptic Processing – Current Good Manufacturing Practice. FDA (2004)

2.3 Institute of Environmental Sciences and Technology (IEST)

IEST-RP-CC001.7: HEPA and ULPA Filters