



ATIS STANDARD

ATIS-0600313.2019(R2024)

**Electrical Protection for Telecommunications
Central Offices and Similar Type Facilities**

AMERICAN NATIONAL STANDARD FOR TELECOMMUNICATIONS



As a leading technology and solutions development organization, the Alliance for Telecommunications Industry Solutions (ATIS) brings together the top global ICT companies to advance the industry's most pressing business priorities. ATIS' nearly 200 member companies are currently working to address the All-IP transition, 5G, network functions virtualization, big data analytics, cloud services, device solutions, emergency services, M2M, cyber security, network evolution, quality of service, billing support, operations, and much more. These priorities follow a fast-track development lifecycle — from design and innovation through standards, specifications, requirements, business use cases, software toolkits, open source solutions, and interoperability testing.

ATIS is accredited by the American National Standards Institute (ANSI). The organization is the North American Organizational Partner for the 3rd Generation Partnership Project (3GPP), a founding Partner of the oneM2M global initiative, a member of the International Telecommunication Union (ITU), as well as a member of the Inter-American Telecommunication Commission (CITEI). For more information, visit www.atis.org.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Notice of Disclaimer & Limitation of Liability

The information provided in this document is directed solely to professionals who have the appropriate degree of experience to understand and interpret its contents in accordance with generally accepted engineering or other professional standards and applicable regulations. No recommendation as to products or vendors is made or should be implied.

NO REPRESENTATION OR WARRANTY IS MADE THAT THE INFORMATION IS TECHNICALLY ACCURATE OR SUFFICIENT OR CONFORMS TO ANY STATUTE, GOVERNMENTAL RULE OR REGULATION, AND FURTHER, NO REPRESENTATION OR WARRANTY IS MADE OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE OR AGAINST INFRINGEMENT OF INTELLECTUAL PROPERTY RIGHTS. ATIS SHALL NOT BE LIABLE, BEYOND THE AMOUNT OF ANY SUM RECEIVED IN PAYMENT BY ATIS FOR THIS DOCUMENT, AND IN NO EVENT SHALL ATIS BE LIABLE FOR LOST PROFITS OR OTHER INCIDENTAL OR CONSEQUENTIAL DAMAGES. ATIS EXPRESSLY ADVISES THAT ANY AND ALL USE OF OR RELIANCE UPON THE INFORMATION PROVIDED IN THIS DOCUMENT IS AT THE RISK OF THE USER.

NOTE - The user's attention is called to the possibility that compliance with this standard may require use of an invention covered by patent rights. By publication of this standard, no position is taken with respect to whether use of an invention covered by patent rights will be required, and if any such use is required no position is taken regarding the validity of this claim or any patent rights in connection therewith. Please refer to <https://www.atis.org/policy/patent-assurances/> to determine if any statement has been filed by a patent holder indicating a willingness to grant a license either without compensation or on reasonable and non-discriminatory terms and conditions to applicants desiring to obtain a license.

ATIS-0600313.2019(R2024), *Electrical Protection for Telecommunications Central Offices and Similar Type Facilities*

Is an American National Standard developed by the ATIS **Sustainability in Telecom: Energy and Protection Committee (STEP)**.

Published by

Alliance for Telecommunications Industry Solutions
1200 G Street, NW, Suite 500
Washington, DC 20005

Copyright © 2024 by Alliance for Telecommunications Industry Solutions
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher. For information contact ATIS at 202.628.6380. ATIS is online at <http://www.atis.org>.

ATIS-0600313.2019(R2024)

(Revision of ATIS-0600313.2013)

American National Standard for Telecommunications

Electrical Protection for Telecommunications Central Offices and Similar Type Facilities

Alliance for Telecommunications Industry Solutions

Approved September 25, 2018

American National Standards Institute, Inc.

Abstract:

Telecommunications central offices, data centers, electronic equipment enclosures (EEE), and similar type facilities are often subjected to disturbances from lightning and AC power line faults, either directly or indirectly, through the communications cables and AC power facilities that serve them. This standard provides the minimum electrical protection, grounding, and bonding criteria necessary to mitigate the disruptive and damaging effects of lightning and AC power faults. It is intended to serve as a guide for designers of such facilities in the application of electrical protection, grounding, and bonding as a function of the electrical environment.

Foreword

The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the standard.

The Alliance for Telecommunication Industry Solutions (ATIS) serves the public through improved understanding between providers, customers, and manufacturers. The Sustainability in Telecom: Energy and Protection (STEP) Committee – formerly the Network Interface, Power, and Protection Committee (NIPP) – engages industry expertise to develop standards and technical reports for telecommunications equipment and environments in the areas of energy efficiency, environmental impacts, power and protection. The work products of STEP enable vendors, operators and their customers to deploy and operate reliable, environmentally sustainable, energy efficient communications technologies. STEP is committed to proactive engagement with national, regional and international standards development organizations and forums that share its scope of work.

The project to establish minimum requirements for the electrical protection of telecommunications outside plant was initiated as a Project Team under Committee STEP Telecommunications and NEP Subcommittee.

Disturbances from lightning and AC power line faults may be disruptive to telecommunications service and may also result in damage to the telecommunications plant and equipment. Telecommunications outside plant is often exposed to such disturbances because of its physical location and frequent joint-use or joint right-of-way installations with power utility outside plant facilities. Telecommunications service providers employ electrical protection measures that are intended to reduce the effects of such disturbances. ANSI C2, *National Electrical Safety Code*[®], covers the safety aspects of the installation, grounding, and bonding of telecommunications outside plant. This standard provides the minimum electrical protection requirements intended to mitigate the disruptive and damaging effects of lightning and AC power faults to telecommunications outside plant. It is not intended that this standard supersede ANSI C2, but that it provide additional information intended to ensure the reliable functioning of the telecommunications outside plant.

Subject matter experts were gathered under the auspices of Committee STEP to determine the minimum satisfactory criteria for the electrical protection of telecommunications outside plant.

Suggestions for improvement of this standard will be welcome. These should be sent to the Alliance for Telecommunications Industry Solutions, STEP, 1200 G Street, NW, Suite 500, Washington DC 20005.

At the time of consensus on this document, STEP which was responsible for its development, had the following leadership:

- E. Gallo, STEP Chair (Ericsson)
- J. Fuller, STEP Vice Chair (AT&T)
- D. Ashton, STEP-NEP Chair (Ericsson)
- J. Fuller, STEP-NEP Vice Chair (AT&T)
- D. Ashton, STEP-NEP Technical Editor (CenturyLink)

The Network Electrical Protection (NEP) Subcommittee was responsible for the development of this document.

Table of Contents

1	SCOPE	1
1.1	TELECOMMUNICATIONS FACILITIES COVERED	1
1.2	APPLICATION OF ELECTRICAL PROTECTION.....	1
1.3	TOPICS NOT COVERED	1
2	REFERENCES	2
2.1	NORMATIVE.....	2
2.2.	INFORMATIVE	2
3	DEFINITIONS	3
4	ACRONYMS	5
5	EXPOSURE	5
5.1	SOURCES OF UNWANTED VOLTAGES & CURRENTS	5
5.1.1	<i>Lightning Exposure</i>	6
5.1.2	<i>Power Contact Exposure</i>	6
5.1.3	<i>Ground Potential Rise (Power-related)</i>	6
5.1.4	<i>Power Induction Exposure</i>	6
5.2	SOURCES OF FACILITY EXPOSURE	7
5.2.1	<i>Exposed Telecommunications Outside Plant</i>	7
5.2.2	<i>Exposed Commercial AC Power</i>	7
5.2.3	<i>Exposed Building Site & Antennas/Towers</i>	7
6	ELECTRICAL PROTECTION CONSIDERATIONS	7
6.1	GENERAL	7
6.2	GROUNDING (EARTHING)	7
6.3	BONDING	7
6.4	PROTECTOR UNITS.....	8
6.5	CURRENT LIMITING DEVICES	8
6.5.1	<i>Heat Coils</i>	8
6.5.2	<i>Solid-State Current Limiters</i>	8
6.6	FUSE LINKS.....	8
7	FACILITIES GROUNDS	8
7.1	GENERAL	8
7.2	GROUNDING (EARTHING) SYSTEM.....	9
7.2.1	<i>Category 1</i>	11
7.2.2	<i>Reference Point 0</i>	12
7.2.3	<i>Category 2</i>	12
7.2.4	<i>Category 3</i>	13
7.2.5	<i>Category 4</i>	13
7.2.6	<i>Category 5</i>	13
7.2.7	<i>Category 6</i>	13
7.2.8	<i>Category 7</i>	13
8	PROTECTION APPLIED TO TRANSMISSION MEDIA ENTERING TELECOMMUNICATIONS FACILITIES	13
8.1	GENERAL	13
8.2	BONDING & GROUNDING (EARTHING)	14
8.2.1	<i>Standard Entrance [see Figure 2(a)]</i>	15
8.2.2	<i>Isolation Entrance [see Figure 2(b)]</i>	15
8.2.3	<i>Insulating Entrance [see Figure 2(c)]</i>	15
8.3	PROTECTORS	15

ATIS-0600313.2019(R2024)

8.4 CURRENT LIMITING DEVICES 15

 8.4.1 *Current Limiting Devices*..... 15

 8.4.2 *Considerations for the Use of Current Limiting Devices*..... 16

8.5 PROTECTION COORDINATION 16

9 PROTECTION APPLIED TO AC POWER SERVING TELECOMMUNICATIONS FACILITIES 17

 9.1 SOURCES OF OVERVOLTAGE ON THE SERVING AC POWER FACILITY 17

 9.1.1 *Lightning*..... 17

 9.1.2 *Other*..... 17

 9.2 DETERMINATION OF EXPOSURE..... 17

 9.3 APPLICATION OF SURGE PROTECTIVE DEVICES..... 17

 9.3.1 *Primary Distribution Class Surge Protective Devices*..... 17

 9.3.2 *Secondary Class Surge Protective Devices*..... 17

10 RADIO TOWER, MICROWAVE TOWER, & WAVEGUIDE GROUNDS 18

 10.1 GENERAL 18

 10.2 STRUCTURE CONFIGURATIONS..... 18

 10.3 STRUCTURE GROUNDING (EARTHING) REQUIREMENTS 18

 10.3.1 *Minimum Grounding (Earthing) Requirements for Free-Standing Structures* 18

 10.3.2 *Supplemental Grounding (Earthing) Requirements (see Figure 3)* 19

 10.3.3 *Rooftop Mounted Application Grounding (Earthing) Requirements* 19

 10.4 EQUIPMENT GROUNDING (EARTHING) REQUIREMENTS 23

 10.5 FEED LINE GROUNDING (EARTHING) REQUIREMENTS..... 23

 10.5.1 *Feed Lines on Metallic Structures* 23

 10.5.2 *Feed Lines on Wooden Structures* 24

 10.5.3 *Feed Line Building Entrance Grounds*..... 24

 10.5.4 *Feed Line Metallic Support Frames Grounds*..... 24

 10.6 TOWER ELECTRICAL ATTACHMENTS 24

 10.7 CORROSION PROTECTION..... 24

11 INSTALLATION CONSIDERATIONS..... 24

 11.1 GENERAL 24

 11.2 GROUNDING (EARTHING) MATERIALS 24

 11.3 GROUNDING (EARTHING) CONDUCTORS 25

 11.4 CONDUIT USE WITH GROUNDING (EARTHING) CONDUCTORS 25

 11.5 GROUND RODS & BARE CONDUCTORS 25

 11.6 CONNECTIONS..... 25

 11.7 OBJECTIVE..... 25

A METRIC EQUIVALENTS OF AWG..... 26

B TELECOMMUNICATION INDUSTRY BLOCK DIAGRAM..... 27

Table of Figures

FIGURE 1 (A) - GROUNDING SYSTEM - GENERAL AND SEQUENCE (CONTINUED)..... 10

FIGURE 1 (B) - GROUNDING SYSTEM - GENERAL AND SEQUENCE (CONCLUDED)..... 12

FIGURE 2 - STANDARD, ISOLATION, AND INSULATING ENTRANCES 14

FIGURE 3 (A) - SUPPLEMENTAL RADIO MICROWAVE TOWER SITE GROUNDING 20

FIGURE 3 (B) - TOWER GUY GROUND..... 22

FIGURE 3 (C) - TOWER SIDE VIEW..... 22

FIGURE 3 (D) - TOWER FRONT VIEW 24

Table of Tables

TABLE 1 - FUSE CABLE REQUIREMENTS)..... 16
TABLE A.1 - COMMON NORTH AMERICAN TELECOM WIRE SIZES AND THEIR METRIC EQUIVALENTS 26

American National Standard
for Telecommunications –

Electrical Protection for Telecommunications Central Offices and Similar Type Facilities

1 Scope

This standard applies to the electrical protection at telecommunications and electrical power conductor entrances to telecommunications central offices and similar type facilities, and to bonding and grounding (earthing) within these facilities. Such electrical protection, bonding, and grounding (earthing) is intended to assist in protecting personnel and telecommunications plant from the effects of lightning surges power contacts, power induction, and ground potential rise. For requirements applying to towers mounted on buildings, see ATIS 0600334 [12], *Electrical Protection of Communications Towers and Associated Structures*.

1.1 Telecommunications Facilities Covered

Telecommunications facilities included are central offices, data centers, HUTS, Controlled Environmental Vaults (CEVs), and electronic equipment enclosures (EEE). These locations would be under the control of the telecommunications service provider. See the informative Annex B for a graphic explanation of facilities covered by this standard and other related NIPP standards.

1.2 Application of Electrical Protection

Not every facility covered by the scope of this document will require the same level of electrical protection. This standard establishes, based upon the electrical environment, the criteria necessary to determine the level of electrical protection to be applied. The electrical protection measures and surge protective device applications presented shall be used where electrical protection is required. Other factors, such as those related to telecommunications service reliability, or local codes and standards, may dictate the need for electrical protection measures that exceed those described in this standard.

1.3 Topics Not Covered

The following topics are not covered by this standard:

- Specific electromagnetic interference mitigation designs;
- Requirements for equipment within the facilities;
- Specifications for equipment grounding (earthing) and bonding topologies. Such specifications are covered in ATIS-0600333 [8], *Grounding and Bonding of Telecommunication Equipment*, clause 8, *Telecommunication Systems Grounding*;
- Device-level specifications for electrical protection apparatus;
- Specifications for power quality or power conditioning;
- Specifications for electrical protection from high-altitude electromagnetic pulse (HEMP) – see ATIS-0600320 [104];
- Electrical protection of telecommunications outside plant -- see ATIS-0600316;
- The customer network interface -- see ATIS-0600318 [103];
- Customer premises equipment; and
- Electrical protection of network operator-type equipment positions – see ATIS-0600321 [105].