



IEEE

IEC/IEEE 63332-387

Edition 1.0 2024-09

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear facilities – Electrical power systems – Diesel generator units applied as standby power sources

Installations nucléaires – Systèmes d'alimentation électrique – Unités de générateur diesel utilisées comme sources d'alimentation de secours





THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2024 IEC, Geneva, Switzerland
Copyright © 2024 IEEE

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing being secured. Requests for permission to reproduce should be addressed to either IEC at the address below or IEC's member National Committee in the country of the requester or from IEEE.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue
New York, NY 10016-5997
United States of America
stds.ipr@ieee.org
www.ieee.org

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews, graphical symbols and the glossary. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 500 terminological entries in English and French, with equivalent terms in 25 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications, symboles graphiques et le glossaire. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 500 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 25 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



IEEE

IEC/IEEE 63332-387

Edition 1.0 2024-09

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Nuclear facilities – Electrical power systems – Diesel generator units applied as standby power sources

Installations nucléaires – Systèmes d'alimentation électrique – Unités de générateur diesel utilisées comme sources d'alimentation de secours

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 00.000

ISBN 978-2-8322-0000-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
1.1 General.....	9
1.2 Inclusions for site testing	10
1.3 Exclusions	11
2 Normative references	11
3 Terms and definitions	12
4 Abbreviated terms	19
5 Principal design criteria	19
5.1 Capability.....	19
5.1.1 General	19
5.1.2 Mechanical and electrical capabilities	19
5.2 Power capabilities.....	22
5.2.1 Application.....	22
5.2.2 Operation	22
5.3 Interactions	23
5.4 Design and application considerations	23
5.5 Design features.....	24
5.5.1 Mechanical and electrical design features.....	24
5.5.2 Control	27
5.5.3 Status information	28
5.5.4 Protection	29
6 Factory production testing	30
6.1 General.....	30
6.1.1 Implementation	30
6.1.2 Documentation	30
6.1.3 Analyses.....	30
6.1.4 Substitutions.....	30
6.2 Specific production tests	31
6.2.1 General	31
6.2.2 Engine tests	31
6.2.3 Generator tests.....	32
6.2.4 Excitation, control, and other accessories /auxiliaries	32
7 Qualification requirements	32
7.1 General.....	32
7.2 Initial type tests.....	32
7.2.1 General	32
7.2.2 Load capability tests	32
7.2.3 Start and load acceptance tests.....	33
7.2.4 Margin tests.....	34
7.3 Ageing	34
7.3.1 General	34
7.3.2 Equipment important to safety	34
7.3.3 Ageing classification.....	34
7.4 Seismic qualification requirements	35

7.5	Ongoing surveillance	35
7.5.1	General	35
7.5.2	Preventive maintenance, inspection, testing, and monitoring	35
7.5.3	Records and analyses	36
7.6	Modifications	36
7.7	Documentation	36
8	Site testing	37
8.1	Testing	37
8.2	Site acceptance testing	38
8.2.1	General	38
8.2.2	Tests	38
8.2.3	Test loads	38
8.3	Pre-operational testing	39
8.3.1	General	39
8.3.2	Reliability test	39
8.3.3	Individual pre-operational tests	39
8.4	Operational testing	39
8.4.1	General	39
8.4.2	Periodic tests	40
8.5	Test description	42
8.5.1	General	42
8.5.2	Slow-start test	42
8.5.3	Load-run test	42
8.5.4	Fast-start test	42
8.5.5	Loss of offsite power (LOOP) test	42
8.5.6	Accident signal test	43
8.5.7	Combined accident and LOOP test	43
8.5.8	Largest-load rejection test	43
8.5.9	Design-load rejection test	43
8.5.10	Endurance and load test	43
8.5.11	Hot restart test	43
8.5.12	Synchronizing test	44
8.5.13	Protective-trip bypass test	44
8.5.14	Protective-trip verification test	44
8.5.15	Test mode override test	44
8.5.16	Independence test	44
8.5.17	Battery testing	44
8.6	Records	45
Annex A (informative)	Method for establishing steady state load profile for diesel-generator units	46
Annex B (informative)	Example of ageing and aged equipment testing	48
B.1	Method qualification	48
B.2	Categorization and records	49
Annex C (informative)	Diesel-generator unit reliability program elements	52
C.1	General	52
C.2	Major reliability program elements	52
C.3	Element discussion	52
Annex D (informative)	Influence of voltage regulating equipment on DG unit surveillance testing	54

D.1	Purpose	54
D.2	Discussion	54
Annex E (informative)	Example of starting times	55
E.1	Basis for minimum and recommended start attempt capacity	55
E.2	Starting air system	55
E.3	DC starting system.....	56
Annex F (informative)	Power quality considerations for diesel generators units and impact on loads	57
F.1	Purpose	57
F.2	DG unit power quality.....	57
F.2.1	General	57
F.2.2	Dynamic voltage and frequency performance during load acceptance or load rejection.....	57
F.2.3	Steady state voltage and frequency	58
F.2.4	Support system performance	58
F.2.5	Load carrying capacity	59
F.2.6	Fuel consumption	59
F.2.7	Load performance considerations	59
F.2.8	Offsite power supply power quality effects on paralleled diesel generator.....	62
Bibliography	64
Figure 1	– Scope diagram.....	10
Table 1	– Design and application considerations.....	23
Table 2	– Recommended load tests	31
Table 3	– Format for component ageing classification (see Annex B).....	35
Table 4	– Site testing	37
Table 5	– Test parameters	41
Table B.1	– Examples of non-safety/important to safety components	49
Table B.2	– Ageing classification of safety class and important to safety components.....	50
Table E.1	– Recommended capacity of starting air system.....	55
Table E.2	– Recommended capacity of DC system	56

INTERNATIONAL ELECTROTECHNICAL COMMISSION

NUCLEAR FACILITIES – ELECTRICAL POWER SYSTEMS: DIESEL GENERATOR UNITS APPLIED AS STANDBY POWER SOURCES

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC document(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. *IEEE documents are made available for use subject to important notices and legal disclaimers (see <https://standards.ieee.org/ipr/disclaimers.html> for more information).*

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations. This Dual Logo International Standard was jointly developed by the IEC and IEEE under the terms of that agreement.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this document, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this document are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

IEC/IEEE 63332-387 was prepared by subcommittee 45A: Instrumentation, control and electrical power systems of nuclear facilities, of IEC technical committee 45: Nuclear instrumentation, in cooperation with Nuclear Power Engineering Committee of the IEEE Power and Energy Society, under the IEC/IEEE Dual Logo Agreement between IEC and IEEE.

This document is published as an IEC/IEEE Dual Logo standard.

This new edition supersedes IEEE Std 387-2017 and therefore constitutes a first edition of the standard published under the IEC/IEEE Dual Logo agreement. This document contains the following technical changes with respect to IEEE Std 387-2017:

- This revision incorporates current practices and lessons learned from the implementation of previous versions of this document by the nuclear industry. Additionally, several issues are clarified or changed in this revision.
- This document defines the methods for design and testing of a diesel generator (DG) unit to provide reasonable assurance that in the event it is required to perform its safety functions during a plant emergency condition, it is readily available and capable given the environments to which it can be exposed. This dual logo standard applies to all electrical equipment important to safety in accordance with IAEA terminology including class 1E equipment in accordance with IEEE classification scheme and classes 1, 2 and 3 in accordance with IEC 61226 classification scheme. This document is generally intended for DGs to be utilised as equipment important to safety located in mild environments. The standard may be used in applications where a highly reliable onsite alternating current (AC) power source is required to maintain plant safety following an event with potential loss of offsite power for an extended duration. The documentation and qualification requirements, however, can be less rigorous or different.
- The definitions and terms used in IEC/IAEA standards and guides have been added to support the terminology used in IEEE standards.
- Incorporation of recent industrial experience in the area of DG unit best practices for maintenance and testing.

The text of this International Standard is based on the following IEC documents:

Draft	Report on voting
45A/1536/FDIS	45A/1553/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the rules given in the ISO/IEC Directives, Part 2, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

a) Technical background, main issues and organization of the standard

This IEC/IEEE international standard defines the standard criteria for the application and testing of diesel generator (DG) units used as standby power supplies in nuclear facilities. This dual logo standard applies to DG units as relevant for electrical equipment important to safety in accordance with IAEA terminology including all equipment important to safety in accordance with the IEEE classification scheme.

The provisions of this document are divided into the following clauses:

- Clause 5: Principal design criteria,
- Clause 6: Factory production testing,
- Clause 7: Qualification requirements,
- Clause 8: Site testing.

This document harmonizes in a unique standard practice formerly given by IEEE Std 387-2017 on sizing, testing, qualification, and operational requirements of diesel engine-driven onsite power sources. This document also considers the general requirements on electrical power systems provided in IEC 63046 and assesses current practices and operating experience on the current fleet of nuclear facilities with a perspective on safety significance of the performance requirements of DG units during accident mitigation.

This document is applicable to the DG units of new nuclear facilities and upgrading or back-fitting of existing facilities. It is intended that the standard be used by operators of nuclear facilities, design engineers, systems evaluators and by licensors.

b) Situation of the current standard in the structure of the IEC/SC 45A standard series

The entry point for the IEC/SC 45A standard series is the two first-level standards providing general requirements on instrumentation and control (IEC 61513) and electrical power systems (IEC 63046) for nuclear facilities.

IEC/IEEE 63332-387 is a second level IEC/SC 45A document under IEC 63046 which focuses on criteria for the application and testing of DG units used for standby power supplies for electrical equipment important to safety in nuclear facilities.

For more details on the structure of the IEC/SC 45A standard series, see paragraph d) of this introduction.

c) Recommendations and limitations regarding the application of the standard

An important concept is that the current fleet of operating reactors with forced cooling and immediate need for alternating current (AC) powered equipment following an emergency or off-normal condition necessitates safety classified onsite power sources. Designs with passive cooling systems preclude the need for immediate AC driven pumps and motors. However, following the events at Fukushima Daiichi nuclear plant, and requirements for design extension conditions, onsite AC power system(s) are required to make up inventory and perform core cooling functions after the passive systems have performed the immediate safety functions at the onset of an event. Diesel engine driven AC power sources can be used to provide the power necessary to perform the functions important to safety in order to maintain safe state conditions in all types of plant designs.

It is important to note that this document establishes no additional functional requirements for safety systems.

To ensure that the standard will continue to be relevant in future years, the emphasis has been placed on issues of principle, rather than specific technologies.

d) Description of the structure of the IEC/SC 45A standard series and relationships with other IEC documents and other bodies' documents (IAEA, ISO)

The IEC/SC 45A standard series comprises a consistent set of documents organised in a hierarchy of four levels. The top-level documents of the IEC/SC 45A standard series are IEC 61513 and IEC 63046, covering respectively general requirements for instrumentation and control (I&C) systems and general requirements for electrical power systems of NPPs. IEC 61513 and IEC 63046 adopt an overall system life-cycle framework and constitute, along with the relevant second-level standards, the nuclear implementation of the basic safety series IEC 61508.

IEC 61513 and IEC 63046 refer directly to other IEC/SC 45A standards for general requirements for specific topics, such as categorization of functions and classification of systems, qualification, separation, defence against common cause failure, control room design, electromagnetic compatibility, human factors engineering, cybersecurity, software and hardware aspects for programmable digital systems, coordination of safety and security requirements and management of ageing.

At a third level, IEC/SC 45A standards not directly referenced by IEC 61513 or by IEC 63046 are standards related to specific requirements for specific equipment, technical methods, or activities. Usually, these documents refer to second-level documents for general requirements and can be used on their own.

A fourth level extending the IEC/SC 45A standard series corresponds to the Technical Reports which are not normative.

The IEC/SC 45A standards series consistently implements and details the safety and security principles and basic aspects provided in the relevant IAEA safety standards and in the relevant documents of the IAEA nuclear security series (NSS). In particular this includes the IAEA safety requirements SSR-2/1 (Rev 1), establishing safety requirements related to the design of nuclear power plants (NPPs), the IAEA safety guide SSG-30 dealing with the safety classification of structures, systems and components in NPPs, the IAEA safety guide SSG-39 dealing with the design of instrumentation and control systems for NPPs, the IAEA safety guide SSG-34 dealing with the design of electrical power systems for NPPs, the IAEA safety guide SSG-51 dealing with human factors engineering in the design of NPPs and the implementing guide NSS42-G for computer security at nuclear facilities. The safety and security terminology and definitions used by the SC 45A standards are consistent with those used by the IAEA.

IEC 61513 and IEC 63046 refer to ISO 9001 as well as to IAEA GSR part 2 and IAEA GS-G-3.1 and IAEA GS-G-3.5 for topics related to quality assurance (QA).

At level 2, regarding nuclear security, IEC 62645 is the entry document for the IEC/SC 45A security standards. It builds upon the valid high-level principles and main concepts of the generic security standards, in particular ISO/IEC 27001 and ISO/IEC 27002; it adapts them and completes them to fit the nuclear context and coordinates with the IEC 62443 series. At level 2, IEC 60964 is the entry document for the IEC/SC 45A control rooms standards, IEC 63351 is the entry document for the human factors engineering standards and IEC 62342 is the entry document for the ageing management standards.

NOTE 1 IEC TR 63400 provides a more comprehensive description of the overall structure of the IEC/SC 45A standards series and of its relationship with other standards bodies and standards.

NUCLEAR FACILITIES – ELECTRICAL POWER SYSTEMS: DIESEL GENERATOR UNITS APPLIED AS STANDBY POWER SOURCES

1 Scope

1.1 General

This document defines the criteria for the application and testing of diesel generator (DG) units used as safety class standby power supplies in nuclear facilities. In general, the standard applies to new nuclear facilities as well as for upgrading or back-fitting of existing facilities. Existing facilities can voluntarily adopt the requirements to enhance the performance capabilities and reliability of the installed DG units. The standard can be used in applications where highly reliable onsite alternating current (AC) power source is required to maintain plant safety following an event with potential loss of offsite power for an extended duration.

This document provides the principal design criteria, the design features, testing, and qualification requirements for the individual DG units that enable them to meet their functional requirements as a part of the standby power supply under the conditions produced by the design basis events cataloged in the plant safety analysis.

Figure 1 shows the boundaries of systems and equipment included in the scope of this document.

The following items are within the scope of this document:

- a) The diesel engine, which includes the following:
 - 1) the flywheel and coupling (if applicable),
 - 2) the combustion air system and supply,
 - 3) the starting system including storage of energy,
 - 4) the starting energy system,
 - 5) the fuel oil supply system (e.g., including the day tank, filters, piping, pumps, valves and strainers between the day tank and the engine injection pumps),
 - 6) the lubricating oil system including keep-warm system,
 - 7) the cooling system (jacket water), starting at the point where the cooling medium is introduced to the DG unit. (For a closed loop water-cooling system (radiator) supplied as part of the DG unit, the starting point is water/air interface),
 - 8) the exhaust system,
 - 9) the governor system;
- b) The generator, which includes the following:
 - 1) the excitation and voltage regulation system,
 - 2) the diesel generator output breaker at the switchgear,
 - 3) the diesel generator grounding (earthing) system;
- c) The local control, protection, and surveillance systems associated with the diesel engine, the generator, and their auxiliary equipment and systems cited above. The design of control systems is not in the scope of this document. However, the functional criterion is provided;
- d) The AC and direct current (DC) distribution systems associated with the diesel engine including the battery (if supplied with the generator) for starting, field flashing, the generator, and their auxiliary equipment and systems cited above, exclusive of the auxiliary power system beyond the generator output breaker;
- e) Fuel oil storage system (e.g., storage tank, transfer pumps, filters, piping, valves, and strainers between the storage tank and the day tank);