



IEEE Standard Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches

IEEE Power & Energy Society

Sponsored by the
Switchgear Committee

C37.46TM

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

29 October 2010

IEEE Std C37.46TM-2010
(Revision of
ANSI C37.46-2000)

IEEE Standard Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches

Sponsor

Switchgear Committee
of the
IEEE Power & Energy Society

Approved 17 June 2010

IEEE-SA Standards Board

Abstract: Specifications for high-voltage (above 1000 V) expulsion and current-limiting type power class fuses, fuse disconnecting switches, their associated fuse links, disconnecting cutouts, and accessories for these devices are covered. All of these devices are intended for use on alternating-current distribution systems.

Keywords: distribution class fuses, distribution fuse cutouts, expulsion fuses, fuse, fuse applications, fuse disconnecting switches, fuse links, high-voltage fuses

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2010 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 29 October 2010. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

PDF: ISBN 978-0-7381-6375-8 STD96094
Print: ISBN 978-0-7381-6376-5 STDPD96094

IEEE prohibits discrimination, harassment and bullying. For more information, visit <http://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>. No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation, or every ten years for stabilization. When a document is more than five years old and has not been reaffirmed, or more than ten years old and has not been stabilized, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon his or her independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration. A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered the official position of IEEE or any of its committees and shall not be considered to be, nor be relied upon as, a formal interpretation of the IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position, explanation, or interpretation of the IEEE.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Recommendations to change the status of a stabilized standard should include a rationale as to why a revision or withdrawal is required. Comments and recommendations on standards, and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854
USA

Authorization to photocopy portions of any individual standard for internal or personal use is granted by The Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

This introduction is not part of IEEE Std C37.46-2010, IEEE Standard Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches.

This standard is a revision of ANSI C37.46-2000, to bring it up to date and in line with present day requirements for high-voltage expulsion and current-limiting power class fuses, fuse links and fuse disconnecting switches. This standard was previously developed by the NEMA High Voltage Fuse Technical Committee. As of 2003 the responsibility for this standard has been transferred to the IEEE High-Voltage Fuse Subcommittee. Liaison was maintained with the International Electrotechnical Commission (IEC) during the development of the revisions in order to incorporate the latest thinking up to the time of publication.

The Switchgear Committee of the IEEE Power & Energy Society has recently sponsored the published standard IEEE Std C37.100.1™-2007, IEEE Standard of Common Requirements for High Voltage Power Switchgear Rated Above 1000 V [B5].^a Although IEEE Std C37.100.1-2007 [B5] is not specifically cited in this document, any information that may apply to fuse devices has been incorporated.

This standard is one of a series of complementary standards covering various types of high-voltage fuses and switches, arranged so that certain standards apply to all devices while other standards provide additional specifications for a particular device. For any device, IEEE Std C37.40™ and IEEE Std C37.41™-2008, plus an additional specification standard covering that device, constitute a complete set of standards for the device.^b In addition, IEEE Std C37.48™ provides application, operation, and maintenance guidance for all the devices, and is supplemented by IEEE Std C37.48.1™, which is an operation, classification, application, and coordination guide for current-limiting fuses.

At the time this standard was approved, this series was comprised of the following standards:

ANSI C37.47, Specifications for High Voltage Current-Limiting Type Distribution Class Fuses and Fuse Disconnecting Switches.

IEEE Std C37.40™, IEEE Standard Service Conditions and Definitions for High-Voltage Fuses, Distribution Enclosed Single-Pole Air Switches, Fuse Disconnecting Switches, and Accessories.

IEEE Std C37.41-2008™, IEEE Standard Design Tests for High-Voltage (>1000 V) Fuses, Fuse and Disconnecting Cutouts, Distribution Enclosed Single-Pole Air Switches, Fuse Disconnecting Switches, and Fuse Links and Accessories Used with These Devices.

IEEE Std C37.42™, IEEE Standard Specifications for High-Voltage (> 1000 V) Expulsion-Type Distribution-Class Fuses, Fuse and Disconnecting Cutouts, Fuse Disconnecting Switches, and Fuse Links, and Accessories Used with These Devices.

IEEE Std C37.43™, IEEE Standard Specifications for High-Voltage Expulsion, Current-Limiting, and Combination-Type Distribution and Power Class External Fuses, with Rated Voltages from 1 kV through 38 kV, Used for the Protection of Shunt Capacitors.

IEEE Std C37.45™, IEEE Standard Specifications for High-Voltage Distribution Class Enclosed Single-Pole Air Switches with Rated Voltages from 1 kV through 8.3 kV.

^a The numbers in brackets correspond to those of the bibliography in Annex A.

^b Information on normative references can be found in Clause 2.

IEEE Std C37.46™, IEEE Standard Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches.

IEEE Std C37.48™, IEEE Guide for Application, Operation, and Maintenance of High-Voltage Fuses, Distribution Enclosed Single-Pole Air Switches, Fuse Disconnecting Switches, and Accessories.

IEEE Std C37.48.1™, IEEE Guide for the Operation, Classification, Application and Coordination of Current-Limiting Fuses with Rated Voltages from 1–38 kV.

NOTE—ANSI C37.47-2000 was developed by NEMA. The responsibility for maintaining this document has been passed to IEEE, and the document will be designated “IEEE Std C37.47™” at its next revision.

Notice to users

Laws and regulations

Users of these documents should consult all applicable laws and regulations. Compliance with the provisions of this standard does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the IEEE. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making this document available for use and adoption by public authorities and private users, the IEEE does not waive any rights in copyright to this document.

Updating of IEEE documents

Users of IEEE standards should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit the IEEE Standards Association web site at <http://ieeexplore.ieee.org/xpl/standards.jsp>, or contact the IEEE at the address listed previously.

For more information about the IEEE Standards Association or the IEEE standards development process, visit the IEEE-SA web site at <http://standards.ieee.org>.

Errata

Errata, if any, for this and all other standards can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/updates/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Interpretations

Current interpretations can be accessed at the following URL: <http://standards.ieee.org/reading/ieee/interp/index.html>.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this standard was submitted to the IEEE-SA Standards Board for approval, the Revision of Fuse Specifications Standards Working Group had the following membership:

Mark W. Stavnes, *Chair*
Frank J. Muench, *Secretary*

Chris Ambrose
Glenn R. Borchardt
Sam Chang
Dan Gardner
Gary W. Haynes

Frank Ladonne
Frank C. Lambert
John G. Leach
James R. Marek
Sean Moody
Donald Parker

R. Neville Parry
Timothy E. Royster
John S. Schaffer
Alan Yerges
Jan A. Zawadzki

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

William J. Ackerman
S. Aggarwal
Chris Ambrose
Robert Barnett
Steven Bezner
William Bloethe
Glenn R. Borchardt
Chris Brooks
Eldridge Byron
Gary L. Donner
Randall Dotson
Dana Dufield
Edgar Dullni
Gary Engmann
Marcel Fortin
Fredric Friend
Edwin Goodwin
James Graham
Randall Groves

Ajit Gwal
Gary Heuston
R. Jackson
Andrew Jones
John Kay
Gael Kennedy
Tanuj Khandelwal
Joseph L. Koepfinger
Jim Kulchisky
Chung-Yiu Lam
John Leach
G. Luri
Daleep Mohla
Georges Montillet
Frank J. Muench
Daniel Mulkey
Jerry Murphy
Michael S. Newman
Joe Nims
T. Olsen

Lorraine Padden
Donald Parker
R. Neville Parry
Iulian Profir
Michael Roberts
Timothy E. Royster
Thomas Rozek
Vincent Saporita
Bartien Sayogo
Gil Shultz
James Smith
Jerry Smith
Mark W. Stavnes
Gary Stoedter
James Swank
John Vergis
Waldemar Von Miller
William H. Walter
Janusz Zawadzki

When the IEEE-SA Standards Board approved this standard on 17 June 2010, it had the following membership:

Robert M. Grow, *Chair*
Richard H. Hulett, *Vice Chair*
Steve M. Mills, *Past Chair*
Judith Gorman, *Secretary*

Karen Bartleson
Victor Berman
Ted Burse
Clint Chaplin
Andy Drozd
Alexander Gelman
Jim Hughes

Young Kyun Kim
Joseph L. Koepfinger*
John Kulick
David J. Law
Hung Ling
Oleg Logvinov
Ted Olsen

Ronald C. Petersen
Thomas Prevost
Jon Walter Rosdahl
Sam Sciacca
Mike Seavey
Curtis Siller
Don Wright

*Member Emeritus

Also included are the following nonvoting IEEE-SA Standards Board liaisons:

Satish Aggarwal, *NRC Representative*
Richard DeBlasio, *DOE Representative*
Michael Janezic, *NIST Representative*

Lisa Perry
IEEE Standards Program Manager, Document Development

Matthew J. Ceglia
IEEE Standards Program Manager, Technical Program Development

Contents

1. Overview	1
1.1 Scope	1
1.2 Purpose	2
1.3 General information	2
1.4 Background	2
1.5 Description of fuse-enclosure packages using expulsion-type indoor power class fuses	2
1.6 Description of fuse-enclosure packages using current-limiting type indoor distribution and power class fuses	3
1.7 Other devices	3
2. Normative references	3
3. General rating information	4
3.1 Ratings of power class fuse supports and fuse disconnecting switches	4
3.2 Ratings of fuse holders, fuse units, refill units, and fuse links for power class fuses	4
3.3 Preferred ratings and performance requirements for power class expulsion and current-limiting type fuses and fuse disconnecting switches	5
4. Design test requirements	9
4.1 Dielectric tests	9
4.2 Interrupting [breaking] tests	9
4.3 Radio-influence tests	11
4.4 Temperature rise tests	11
4.5 Time-current tests	12
4.6 Liquid tightness tests for liquid immersed current-limiting type power class fuses	12
5. Time-current-characteristic requirements for power class fuse refill units, fuse units, and fuse links	12
5.1 General	12
5.2 Minimum melting and total clearing time-current-characteristics for refill units, fuse units, and fuse links not assigned a specific letter designation	12
5.3 Melting [pre-arcing] time-current-characteristics for E-rated fuses	13
5.4 Melting [pre-arcing] time-current-characteristics for R-rated fuses	13
5.5 Identification for E-rated or R-rated fuse units, refill units or fuse links	13
5.6 Melting current tolerance	13
6. Conformance tests	14
7. Construction requirements	14
7.1 Break distance of power class fuse supports and fuse disconnecting switches	14
7.2 Shipment of power class fuse supports	14
7.3 Base mounting dimensions	14

8. Nameplate marking	15
8.1 Fuse supports or fuse disconnecting switches	15
8.2 Fuse units or refill units	15
8.3 Fuse holders	16
8.4 Fuse links	16
9. Application, operation, and maintenance guidelines	16
9.1 General	16
9.2 Pole-to-pole [phase-to-phase] centerline spacings and clearances	16
9.3 Paralleling of fuses	18
Annex A (informative) Bibliography	19

IEEE Standard Specifications for High-Voltage (>1000 V) Expulsion and Current-Limiting Power Class Fuses and Fuse Disconnecting Switches

IMPORTANT NOTICE: This standard is not intended to ensure safety, security, health, or environmental protection. Implementers of the standard are responsible for determining appropriate safety, security, environmental, and health practices or regulatory requirements.

This IEEE document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notice" or "Important Notices and Disclaimers Concerning IEEE Documents." They can also be obtained on request from IEEE or viewed at <http://standards.ieee.org/IPR/disclaimers.html>.

1. Overview

1.1 Scope

This standard establishes specifications for high-voltage (above 1000 V) expulsion and current-limiting type power class fuses, and accessories. All of these devices are intended for use on alternating current systems. These specifications apply to the following specific types of equipment:

- a) Power class expulsion-type fuses
- b) Power class current-limiting type fuses
- c) Power class fuse disconnecting switches
- d) Item a) through item c) used in fuse-enclosure packages (FEPs)
- e) Fuse supports, fuse holders, fuse hooks, fuse units, and refill units, of the type intended for use with power class fuses and fuse disconnecting switches
- f) Disconnecting devices created by the use of a removable switch blade in a power class fuse support
- g) Fuse links when used exclusively with power class fuses and fuse disconnecting switches