

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 6-24: Application layer protocol specification – Type 24 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 6-24: Spécification du protocole de la couche application – Eléments de
type 24**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Recherche de publications IEC -

webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études, ...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et une fois par mois par email.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Découvrez notre puissant moteur de recherche et consultez gratuitement tous les aperçus des publications. Avec un abonnement, vous aurez toujours accès à un contenu à jour adapté à vos besoins.

Electropedia - www.electropedia.org

Le premier dictionnaire d'électrotechnologie en ligne au monde, avec plus de 22 300 articles terminologiques en anglais et en français, ainsi que les termes équivalents dans 19 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 6-24: Application layer protocol specification – Type 24 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 6-24: Spécification du protocole de la couche application – Eléments de
type 24**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.040.40, 35.100.70, 35.110

ISBN 978-2-8322-7816-1

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications	9
1.3 Conformance	10
2 Normative references	10
3 Terms, definitions, symbols, abbreviated terms, and conventions	10
3.1 Referenced terms and definitions.....	10
3.1.1 Terms and definitions from ISO/IEC 7498-1	11
3.1.2 Terms and definitions from ISO/IEC 9545	11
3.1.3 Terms and definitions from ISO/IEC 8824-1	11
3.1.4 Terms and definitions from ISO/IEC 10731	11
3.1.5 Terms and definitions from ISO/IEC 19501	12
3.2 Additional terms and definitions	12
3.3 Abbreviations and symbols	17
3.4 Conventions.....	19
3.4.1 General conventions.....	19
3.4.2 PDU data type conventions.....	19
3.4.3 State machine conventions	19
4 Abstract syntax.....	22
4.1 Basic Data types.....	22
4.2 FAL PDU types	23
4.2.1 Top of APDU types: _APDU.....	23
4.2.2 PDUs for field device control service	24
4.2.3 PDUs for message service.....	37
4.3 Detailed definitions of _FDCService-PDUs.....	38
4.3.1 Short PDU type.....	38
4.3.2 Long PDU type	45
4.3.3 Enhanced PDU type	48
4.3.4 SubCommand PDU type	58
4.3.5 Short PDU type II.....	59
4.4 Device profile.....	66
5 Transfer syntax.....	66
5.1 Concepts	66
5.2 Encode rules.....	66
5.2.1 INTEGER and its subtypes	66
5.2.2 REAL type and its subtypes	68
5.2.3 BIT STRING type.....	69
5.2.4 OCTET STRING type and IA5String type.....	70
5.2.5 NULL type	71
5.2.6 Structure type and Array type	71
6 Structure of FAL protocol state machine	71
7 AP-context state machine (APC SM)	73
7.1 Overview.....	73
7.2 State descriptions	74

7.3	Triggering events	75
7.4	Action descriptions at state transitions	75
8	FAL service protocol machines (FSPM)	77
8.1	Overview.....	77
8.2	Field Device Control Protocol Machine (FDC PM)	77
8.2.1	Protocol overview	77
8.2.2	Cyclic communication mode.....	78
8.2.3	Event driven communication mode	82
8.2.4	Master Protocol Machine (FDCPM-M).....	83
8.2.5	Slave Protocol Machine (FDCPM-S)	92
8.2.6	Monitor Protocol Machine (FDCPM-MN)	102
8.2.7	Error procedure summary	104
8.3	Message Protocol Machine (MSGPM).....	106
8.3.1	Protocol overview	106
8.3.2	Requester Protocol Machine (MSGPM-RQ)	108
8.3.3	Responder Protocol Machine (MSGPM-RS).....	111
9	Application relationship protocol machine (ARPM).....	113
9.1	General.....	113
9.2	ARPM for FDC ASE	114
9.2.1	Overview	114
9.2.2	ARPM for FDC Master (ARPM-FDCM).....	116
9.2.3	ARPM for FDC Slave (ARPM-FDCS)	122
9.2.4	ARPM for FDC Monitor (ARPM-FDCMN).....	129
9.3	ARPM for MSG ASE (ARPM-MSG)	131
9.3.1	State descriptions	131
9.3.2	Triggering events.....	132
9.3.3	Action descriptions at state transitions.....	133
10	DLL mapping protocol machine (DMPM).....	134
	Annex A (informative) Device profile and FDC command sets	135
	Annex B (normative) Virtual memory space and Device Information	137
	B.1 Overview.....	137
	B.2 Device Information.....	137
	B.2.1 Device identifier area structure	137
	B.2.2 Detail specifications of device IDs	138
	Annex C (informative) Basic message function	144
	Bibliography.....	145
	Figure 1 – Tree structure of APDU types.....	24
	Figure 2 – Encode of Integer subtypes.....	67
	Figure 3 – Example of transfer of INTEGER value	67
	Figure 4 – Encode of Unsigned subtypes	68
	Figure 5 – <i>Float</i> ₃₂ type encode.....	68
	Figure 6 – <i>Float</i> ₆₄ type encode.....	69
	Figure 7 – Bit field definition example with named bits	70
	Figure 8 – Bit field definition example with field size	70
	Figure 9 – SEQUENCE type encode	71

Figure 10 – Structure of FAL protocol state machines	73
Figure 11 – Statechart diagram of APCSM.....	74
Figure 12 – Example communication cycle of FDC master AP.....	79
Figure 13 – Example communication cycle of FDC slave AP.....	79
Figure 14 – Synchronous command communication in sync state	80
Figure 15 – Asynchronous command communication in sync state.....	81
Figure 16 – Asynchronous command communication in async state.....	82
Figure 17 – Event-driven communication	83
Figure 18 – Statechart diagram of FDCPM-M.....	84
Figure 19 – Statechart diagram of FDCPM-S	93
Figure 20 – Statechart diagram of FDCPM-MN	102
Figure 21 – PDU transmission flow for user message	107
Figure 22 – PDU transmission flow for one-way message	108
Figure 23 – Statechart diagram of MSGPM-RQ.....	109
Figure 24 – Statechart diagram of MSGPM-RS	111
Figure 25 – Example of single transfer process.....	114
Figure 26 – Example of dual transfer process	114
Figure 27 – Example of Synchronous command communication.....	115
Figure 28 – Timing chart for individual communication cycle setting.....	116
Figure 29 – Statechart diagram of ARPM-FDCM	117
Figure 30 – Statechart diagram of ARPM-FDCS.....	123
Figure 31 – Statechart diagram of ARPM-FDCMN.....	129
Figure 32 – Statechart diagram of ARPM-MSG	132
Figure B.1 – Memory map of virtual memory space.....	137
Figure B.2 – Memory map of device ID area	138
Table 1 – State transition descriptions	20
Table 2 – Description of state machine elements	20
Table 3 – Conventions used in state machines	21
Table 4 – Mapping for Protocol State Machines	72
Table 5 – State descriptions of APC SM	74
Table 6 – Trigger event descriptions of APC SM	75
Table 7 – Transitions of APC SM	75
Table 8 – FDC protocol mode	77
Table 9 – State descriptions of FDCPM-M.....	84
Table 10 – Trigger event descriptions of FDCPM-M	86
Table 11 – Transitions of main SM of FDCPM-M.....	87
Table 12 – Transitions of submachine of FDCPM-M.....	89
Table 13 – State descriptions of FDCPM-S	93
Table 14 – Trigger event descriptions of FDCPM-S.....	94
Table 15 – Transitions of main SM of FDCPM-S	95
Table 16 – Transitions of submachine of FDCPM-S	97
Table 17 – State descriptions of FDCPM-MN	102

Table 18 – Trigger event descriptions of FDCPM-MN..... 103

Table 19 – Transitions of main SM of FDCPM-MN 103

Table 20 – Transitions of submachine of FDCPM-MN 104

Table 21 – State descriptions of MSGPM-RQ..... 109

Table 22 – Trigger event descriptions of MSGPM-RQ 110

Table 23 – Transitions of MSGPM-RQ 110

Table 24 – State descriptions of MSGPM-RS 112

Table 25 – Trigger event descriptions of MSGPM-RS..... 112

Table 26 – Transitions of MSGPM-RS..... 113

Table 27 – State descriptions of ARPM-FDCM 117

Table 28 – Trigger event descriptions of ARPM-FDCM 119

Table 29 – Transitions of main SM of ARPM-FDCM 120

Table 30 – Transitions of submachine of ARPM-FDCM 121

Table 31 – State descriptions of ARPM-FDCS 123

Table 32 – Trigger event descriptions of ARPM-FDCS 125

Table 33 – Transitions of main SM of ARPM-FDCS..... 126

Table 34 – Transitions of submachine of ARPM-FDCS..... 127

Table 35 – State descriptions of ARPM-FDCMN 129

Table 36 – Trigger event descriptions of ARPM-FDCMN 130

Table 37 – Transitions of main SM of ARPM-FDCMN..... 130

Table 38 – Transitions of submachine of ARPM-FDCMN..... 131

Table 39 – State descriptions of ARPM-MSG 132

Table 40 – Trigger event descriptions of ARPM-MSG..... 133

Table 41 – Transitions of ARPM-MSG..... 133

Table A.1 – Example of registered device profiles 135

Table A.2 – Example command list of the profile '00'H 136

Table B.1 – Specifications of device IDs 138

Table C.1 – Example of message command set..... 144

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-24: Application layer protocol specification – Type 24 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in the IEC 61784-1 series and the IEC 61784-2 series.

IEC 61158-6-24 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation. It is an International Standard.

This second edition cancels and replaces the first edition published in 2014. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- addition of a new PDU type which called "Short PDU type II" in 4.2;
- update of Table 4;
- addition of examples of Synchronous Command communication in 9.2.1, Figure 27 and Figure 28.

The text of this International Standard is based on the following documents:

Draft	Report on voting
65C/1204/FDIS	65C/1245/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

This document is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the "three-layer" fieldbus reference model described in IEC 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this document is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementers and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This document is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this document together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems can work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-24: Application layer protocol specification – Type 24 elements

1 Scope

1.1 General

The Fieldbus Application Layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a "window between corresponding application programs".

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 24 fieldbus. The term "time-critical" is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This document defines in an abstract way the externally visible behavior provided by the Type 24 fieldbus application layer in terms of

- the abstract syntax defining the application layer protocol data units conveyed between communicating application entities,
- the transfer syntax defining the application layer protocol data units conveyed between communicating application entities,
- the application context state machines defining the application service behavior visibly between communicating application entities, and
- the application relationship state machines defining the communication behavior visibly between communicating application entities.

The purpose of this document is to define the protocol provided to

- define the representation-on-wire of the service primitives defined in IEC 61158-5-24, and
- define the externally visible behavior associated with their transfer.

This document specifies the protocol of the Type 24 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI Application Layer Structure (ISO/IEC 9545).

1.2 Specifications

The principal objective of this document is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-24.

A secondary objective is to provide migration paths from previously existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in the IEC 61158-6 series.